

year	scheme ic	scheme	kpi code	swim cod	indicator title	value	units	comments
2023	11834	Bowen Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
2023	11834	Bowen Potable Water Scheme	QG1.1	AS2	Length water mains	217.1	km	
2023	11834	Bowen Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	16.5	ML/day	
2023	11834	Bowen Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	17	ML	
								Values inputted into template provided by Qldwater.
								Template provided follows KPI definitions.
2023	11834	Bowen Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	375.3	ML	
2023	11834	Bowen Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	25.8	per 100 km water main	
2023	11834	Bowen Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	0.4	per 1000 connections	
2023	11834	Bowen Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	3.5	per 1000 connections	
2023	11834	Bowen Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	6.8	per 1000 connections	
2023	11834	Bowen Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	8.6	per 1000 connections	
2023	11834	Bowen Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	4.549	000s	
2023	11834	Bowen Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.589	000s	
2023	11834	Bowen Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
2023	11834	Bowen Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	1.6	per 1000 connections	
2023	11834	Bowen Potable Water Scheme	QG4.1(valu	PR3	Fixed charge: water value	652	\$/annum	
2023	11834	Bowen Potable Water Scheme	QG4.1(text	PR5	Fixed charge: water description	charge by p	Text	
2023	11834	Bowen Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	2763.3	ML	
2023	11834	Bowen Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	0	ML	
2023	11834	Bowen Potable Water Scheme	QG1.5	WA201	Maximum daily demand	9.4	ML/day	
2023	11834	Bowen Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2023	11834	Bowen Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	11834	Bowen Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	2567.7	ML	
2023	11834	Bowen Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	1298.8	ML	
2023	11834	Bowen Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	880.8	ML	
2023	11834	Bowen Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
2023	11834	Bowen Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	2763.3	ML	
2023	11834	Bowen Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	NR	days	
2023	11834	Bowen Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
2023	11834	Bowen Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
2023	11834	Bowen Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2023	11834	Bowen Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
2023	11834	Bowen Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
2023	11834	Bowen Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	11834	Bowen Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	11834 Bowen Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
2023	11834 Bowen Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
2023	11834 Bowen Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
2023	11834 Bowen Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
2023	11834 Bowen Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
2023	11834 Bowen Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
2023	11834 Bowen Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Contingency available from Don River bores, chlorinated then direct into reticulations system, can be implemented within 1 day.
2023	1238 Cannonvale Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
2023	1238 Cannonvale Potable Water Scheme	QG1.1	AS2	Length water mains	137.7	km	
2023	1238 Cannonvale Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	11.5	ML/day	
2023	1238 Cannonvale Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	20.34	ML	Values inputted into template provided by Qldwater.
2023	1238 Cannonvale Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	416.3	ML	Template provided follows KPI definitions.
2023	1238 Cannonvale Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	29	per 100 km water main	
2023	1238 Cannonvale Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	1.8	per 1000 connections	
2023	1238 Cannonvale Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	8.3	per 1000 connections	
2023	1238 Cannonvale Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	10.9	per 1000 connections	
2023	1238 Cannonvale Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	58.1	per 1000 connections	
2023	1238 Cannonvale Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	5.85	000s	
2023	1238 Cannonvale Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.677	000s	
2023	1238 Cannonvale Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	92	%	
2023	1238 Cannonvale Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0.5	per 1000 connections	
2023	1238 Cannonvale Potable Water Scheme	QG4.1(valu PR3		Fixed charge: water value	652	\$/annum	
2023	1238 Cannonvale Potable Water Scheme	QG4.1(text PR5		Fixed charge: water description	charge by p	Text	
2023	1238 Cannonvale Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	813.4	ML	
2023	1238 Cannonvale Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	485	ML	
2023	1238 Cannonvale Potable Water Scheme	QG1.5	WA201	Maximum daily demand	4.8	ML/day	
2023	1238 Cannonvale Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	1386.7	ML	Potable Water imported from Proserpine PWS
2023	1238 Cannonvale Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	1238 Cannonvale Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	1377	ML	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	1238 Cannonvale Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	1495.7	ML	
2023	1238 Cannonvale Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	837.9	ML	
2023	1238 Cannonvale Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
2023	1238 Cannonvale Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	2685	ML	
2023	1238 Cannonvale Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	NR	days	
2023	1238 Cannonvale Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
2023	1238 Cannonvale Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	365	days	
2023	1238 Cannonvale Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2023	1238 Cannonvale Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
2023	1238 Cannonvale Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
2023	1238 Cannonvale Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	1238 Cannonvale Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	Resourcing issues due to unforeseen and out of councils control circumstances in 2022-23.
2023	1238 Cannonvale Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	Water demand forecasts have been undertaken in Sept 2023.
2023	1238 Cannonvale Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
2023	1238 Cannonvale Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
2023	1238 Cannonvale Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
2023	1238 Cannonvale Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
2023	1238 Cannonvale Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
2023	1238 Cannonvale Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Contingency available from existing bores, chlorinated then direct into reticulations system, can be implemented within 1 day.
2023	1239 Collinsville Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
2023	1239 Collinsville Potable Water Scheme	QG1.1	AS2	Length water mains	49.8	km	
2023	1239 Collinsville Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	6.1	ML/day	
2023	1239 Collinsville Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	7.5	ML	Values inputted into template provided by Qldwater.
2023	1239 Collinsville Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	155.8	ML	Template provided follows KPI definitions.
2023	1239 Collinsville Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	36.1	per 100 km water main	
2023	1239 Collinsville Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
2023	1239 Collinsville Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0.8	per 1000 connections	

year	scheme ic	scheme	kpi code	swim cod	indicator title	value	units	comments
2023	1239	Collinsville Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	3.2	per 1000 connections	
2023	1239	Collinsville Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	103.8	per 1000 connections	
2023	1239	Collinsville Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	1.075	000s	
2023	1239	Collinsville Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.177	000s	
2023	1239	Collinsville Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
2023	1239	Collinsville Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
2023	1239	Collinsville Potable Water Scheme	QG4.1(value	PR3	Fixed charge: water value	652	\$/annum	
2023	1239	Collinsville Potable Water Scheme	QG4.1(text	PR5	Fixed charge: water description	charge by p	Text	
2023	1239	Collinsville Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	861	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	0	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.5	WA201	Maximum daily demand	3.3	ML/day	
2023	1239	Collinsville Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	801.4	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	254.1	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	387.5	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
2023	1239	Collinsville Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	861	ML	
2023	1239	Collinsville Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	NR	days	
2023	1239	Collinsville Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
2023	1239	Collinsville Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
2023	1239	Collinsville Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2023	1239	Collinsville Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
2023	1239	Collinsville Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
2023	1239	Collinsville Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	1239	Collinsville Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	Resourcing issues due to unforeseen and out of councils control circumstances in 2022-23.
2023	1239	Collinsville Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	Water demand forecasts have been undertaken in Sept 2023.
2023	1239	Collinsville Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
2023	1239	Collinsville Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
2023	1239	Collinsville Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
2023	1239	Collinsville Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
2023	1239	Collinsville Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
							Contingency available from an existing bore, chlorinated then direct into reticulations system can be implemented within 7 days, trucking of potable water available from other schemes.
2023	1239	Collinsville Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no
2023	11835	Proserpine Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count
2023	11835	Proserpine Potable Water Scheme	QG1.1	AS2	Length water mains	69.3	km
2023	11835	Proserpine Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	14	ML/day
2023	11835	Proserpine Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	5.7	ML
							Values inputted into template provided by Qldwater. Template provided follows KPI definitions.
2023	11835	Proserpine Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	12	ML
2023	11835	Proserpine Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	17.3	per 100 km water main
2023	11835	Proserpine Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	2	per 1000 connections
2023	11835	Proserpine Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	7	per 1000 connections
2023	11835	Proserpine Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	11	per 1000 connections
2023	11835	Proserpine Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	58.1	per 1000 connections
2023	11835	Proserpine Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	1.671	000s
2023	11835	Proserpine Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.324	000s
2023	11835	Proserpine Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	92	%
2023	11835	Proserpine Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0.5	per 1000 connections
2023	11835	Proserpine Potable Water Scheme	QG4.1(val	PR3	Fixed charge: water value	652	\$/annum
2023	11835	Proserpine Potable Water Scheme	QG4.1(text	PR5	Fixed charge: water description	charge by p	Text
2023	11835	Proserpine Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	633.2	ML
2023	11835	Proserpine Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	1191.5	ML
2023	11835	Proserpine Potable Water Scheme	QG1.5	WA201	Maximum daily demand	6.8	ML/day
2023	11835	Proserpine Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML
2023	11835	Proserpine Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	1386.7	ML
							Potable water exported to Cannonvale PWS
2023	11835	Proserpine Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	1900.7	ML
2023	11835	Proserpine Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	334.8	ML
2023	11835	Proserpine Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	164.6	ML
2023	11835	Proserpine Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML
2023	11835	Proserpine Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	1824.7	ML
2023	11835	Proserpine Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	NR	days
2023	11835	Proserpine Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days
2023	11835	Proserpine Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	365	days

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	11835 Proserpine Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2023	11835 Proserpine Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
2023	11835 Proserpine Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
2023	11835 Proserpine Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	11835 Proserpine Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	11835 Proserpine Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	Resourcing issues due to unforeseen and out of councils control circumstances in 2022-23. Water demand forecasts have been undertaken in Sept 2023.
2023	11835 Proserpine Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
2023	11835 Proserpine Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
2023	11835 Proserpine Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
2023	11835 Proserpine Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
2023	11835 Proserpine Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
2023	11835 Proserpine Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Contingency available from existing bores, chlorinated then direct into reticulations system, can be implemented within 1 day. Additional network under 'Greening & Growing Bowen' project
2023	9711 Bowen Effluent Reuse Scheme	QG1.1	AS2	Length water mains	8.9	km	
2023	9711 Bowen Effluent Reuse Scheme	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
2023	9711 Bowen Effluent Reuse Scheme	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
2023	9711 Bowen Effluent Reuse Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	9711 Bowen Effluent Reuse Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
2023	9711 Bowen Effluent Reuse Scheme	QG1.13	CS2	Connected residential properties: water	NR	000s	
2023	9711 Bowen Effluent Reuse Scheme	QG1.14	CS3	Connected non-residential properties: water	0.003	000s	
2023	9711 Bowen Effluent Reuse Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
2023	9711 Bowen Effluent Reuse Scheme	QG4.1(text	PR3	Fixed charge: water value	NR	\$/annum	
2023	9711 Bowen Effluent Reuse Scheme	QG4.1(text	PR5	Fixed charge: water description	No Charge	Text	
2023	9711 Bowen Effluent Reuse Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2023	9711 Bowen Effluent Reuse Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	9711 Bowen Effluent Reuse Scheme	QG1.11	WA26	Volume recycled sewage supplied: all	217.4	ML	
2023	9711 Bowen Effluent Reuse Scheme	QG1.12	WA7	Volume water sourced: all	217.4	ML	
2023	9710 Cannonvale Effluent reuse	QG1.1	AS2	Length water mains	0	km	
2023	9710 Cannonvale Effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	9710 Cannonvale Effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
2023	9710 Cannonvale Effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	9710 Cannonvale Effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
2023	9710 Cannonvale Effluent reuse	QG1.13	CS2	Connected residential properties: water	NR	000s	
2023	9710 Cannonvale Effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0	000s	
2023	9710 Cannonvale Effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
2023	9710 Cannonvale Effluent reuse	QG4.1(value PR3		Fixed charge: water value	NR	\$/annum	
2023	9710 Cannonvale Effluent reuse	QG4.1(text PR5		Fixed charge: water description	No Charge	Text	
2023	9710 Cannonvale Effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2023	9710 Cannonvale Effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	9710 Cannonvale Effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	0	ML	
2023	9710 Cannonvale Effluent reuse	QG1.12	WA7	Volume water sourced: all	0	ML	
2023	11844 Collinsville Effluent reuse	QG1.1	AS2	Length water mains	1.3	km	
2023	11844 Collinsville Effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
2023	11844 Collinsville Effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
2023	11844 Collinsville Effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	11844 Collinsville Effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
2023	11844 Collinsville Effluent reuse	QG1.13	CS2	Connected residential properties: water	NR	000s	
2023	11844 Collinsville Effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0.001	000s	
2023	11844 Collinsville Effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
2023	11844 Collinsville Effluent reuse	QG4.1(value PR3		Fixed charge: water value	NR	\$/annum	
2023	11844 Collinsville Effluent reuse	QG4.1(text PR5		Fixed charge: water description	No Charge	Text	
2023	11844 Collinsville Effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2023	11844 Collinsville Effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	11844 Collinsville Effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	96.4	ML	
2023	11844 Collinsville Effluent reuse	QG1.12	WA7	Volume water sourced: all	96.4	ML	
2023	11845 Proserpine Effluent reuse	QG1.1	AS2	Length water mains	1.5	km	
2023	11845 Proserpine Effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
2023	11845 Proserpine Effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
2023	11845 Proserpine Effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	11845 Proserpine Effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
2023	11845 Proserpine Effluent reuse	QG1.13	CS2	Connected residential properties: water	NR	000s	
2023	11845 Proserpine Effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0	000s	
2023	11845 Proserpine Effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
2023	11845 Proserpine Effluent reuse	QG4.1(value PR3		Fixed charge: water value	NR	\$/annum	
2023	11845 Proserpine Effluent reuse	QG4.1(text PR5		Fixed charge: water description	No Charge	Text	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	11845 Proserpine Effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2023	11845 Proserpine Effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
2023	11845 Proserpine Effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	0	ML	
2023	11845 Proserpine Effluent reuse	QG1.12	WA7	Volume water sourced: all	0	ML	
2023	1060 Bowen sewer treatment plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	20	per 100 km sewer mains	
2023	1060 Bowen sewer treatment plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
2023	1060 Bowen sewer treatment plant	QG1.2	AS5	Length sewerage mains and channels	134.9	km	
2023	1060 Bowen sewer treatment plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	1.6	per 1000 connections	
2023	1060 Bowen sewer treatment plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	1060 Bowen sewer treatment plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	1.8	per 1000 connections	
2023	1060 Bowen sewer treatment plant	QG1.15	CS6	Connected residential properties: sewerage	3.625	000s	
2023	1060 Bowen sewer treatment plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
2023	1060 Bowen sewer treatment plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.243	000s	
2023	1060 Bowen sewer treatment plant	QG4.2(valu	PR31	Fixed charge: sewerage value	900	\$/annum	
2023	1060 Bowen sewer treatment plant	QG4.2(text	PR40	Fixed charge: sewerage description	Charge by F	Text	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	9.8	per 100 km sewer mains	
2023	11836 Cannonvale Waste Water Treatment Plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
2023	11836 Cannonvale Waste Water Treatment Plant	QG1.2	AS5	Length sewerage mains and channels	133.3	km	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	0.5	per 1000 connections	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	1.2	per 1000 connections	
2023	11836 Cannonvale Waste Water Treatment Plant	QG1.15	CS6	Connected residential properties: sewerage	5.346	000s	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
2023	11836 Cannonvale Waste Water Treatment Plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.485	000s	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.2(valu	PR31	Fixed charge: sewerage value	900	\$/annum	
2023	11836 Cannonvale Waste Water Treatment Plant	QG4.2(text	PR40	Fixed charge: sewerage description	Charge by F	Text	
2023	11837 Collinsville Sewer treatment plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	15.1	per 100 km sewer mains	
2023	11837 Collinsville Sewer treatment plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
2023	11837 Collinsville Sewer treatment plant	QG1.2	AS5	Length sewerage mains and channels	39.7	km	
2023	11837 Collinsville Sewer treatment plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	0.9	per 1000 connections	
2023	11837 Collinsville Sewer treatment plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	11837 Collinsville Sewer treatment plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0.9	per 1000 connections	
2023	11837 Collinsville Sewer treatment plant	QG1.15	CS6	Connected residential properties: sewerage	1.018	000s	
2023	11837 Collinsville Sewer treatment plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
2023	11837 Collinsville Sewer treatment plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.074	000s	
2023	11837 Collinsville Sewer treatment plant	QG4.2(valu	PR31	Fixed charge: sewerage value	900	\$/annum	

year	scheme ic	scheme	kpi code	swim cod	indicator title	value	units	comments
2023	11837	Collinsville Sewer treatment plant	QG4.2(text	PR40	Fixed charge: sewerage description			Charge by F Text
2023	1058	Proserpine Sewer Treatment Plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	21.1	per 100 km sewer mains	
2023	1058	Proserpine Sewer Treatment Plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
2023	1058	Proserpine Sewer Treatment Plant	QG1.2	AS5	Length sewerage mains and channels	47.4	km	
2023	1058	Proserpine Sewer Treatment Plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	1.3	per 1000 connections	
2023	1058	Proserpine Sewer Treatment Plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
2023	1058	Proserpine Sewer Treatment Plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	1.3	per 1000 connections	
2023	1058	Proserpine Sewer Treatment Plant	QG1.15	CS6	Connected residential properties: sewerage	1.425	000s	
2023	1058	Proserpine Sewer Treatment Plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
2023	1058	Proserpine Sewer Treatment Plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.17	000s	
2023	1058	Proserpine Sewer Treatment Plant	QG4.2(valu	PR31	Fixed charge: sewerage value	900	\$/annum	
2023	1058	Proserpine Sewer Treatment Plant	QG4.2(text	PR40	Fixed charge: sewerage description			Charge by F Text
2023	1375	Whitsunday Regional Council WSP-wide	QG1.4a	AS1	Number water treatment plants: providing full treatment	4	Count	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.1	AS2	Length water mains	485.6	km	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	15.8	per 100 km sewer mains	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.3	AS4	Number sewage treatment plants	4	Count	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.4b	AS47	Capacity of water treatment plants	48.1	ML/day	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.7	AS48	Total potable water storage volume	50.54	ML	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.2	AS5	Length sewerage mains and channels	355.2	km	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.23	AS56	Volume water lost: potable water	959.4	ML	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.5	AS8	Water main breaks per 100 km water main	25.9	per 100 km water main	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.12	CS10	Water service complaints per 1000 connections	1.2	per 1000 connections	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.13	CS11	Sewerage service complaints per 1000 connections	1	per 1000 connections	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	5.8	per 1000 connections	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	10	per 1000 connections	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.7	CS17	Average frequency unplanned interruptions: water	44.9	per 1000 connections	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.13	CS2	Connected residential properties: water	13.145	000s	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.14	CS3	Connected non-residential properties: water	1.767	000s	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.15	CS6	Connected residential properties: sewerage	11.414	000s	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.8a	CS66	Percent CSS response target met: water incidents	96	%	
2023	1375	Whitsunday Regional Council WSP-wide	QG1.16	CS7	Connected non-residential properties: sewerage	0.972	000s	
2023	1375	Whitsunday Regional Council WSP-wide	QG4.10	CS9	Water quality complaints per 1000 connections	0.8	per 1000 connections	
2023	1375	Whitsunday Regional Council WSP-wide	QG3.9	FN1	Revenue: all (NPR) water	22066.73	\$/,000	
2023	1375	Whitsunday Regional Council WSP-wide	QG3.6	FN10	Nominal written down replacement cost: fixed sewerage assets	156995.9	\$/,000	
2023	1375	Whitsunday Regional Council WSP-wide	QG3.11	FN11	Costs: operating water per connection	784.69	\$/connection	
2023	1375	Whitsunday Regional Council WSP-wide	QG3.12	FN12	Costs: operating sewerage per connection	715.35	\$/connection	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	1375 Whitsunday Regional Council WSP-wide	QG3.1	FN14	Capital expenditure: water supply	1181.976	\$,000	Resourcing issues due to unforeseen and out of councils control circumstances in 2022-23. STP membrane replacement completed in 2022-23
2023	1375 Whitsunday Regional Council WSP-wide	QG3.2	FN15	Capital expenditure: sewerage	2974.716	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.10	FN2	Revenue: all (NPR) sewerage	18445.74	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.3	FN26	Capital works grants: water	189.921	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.4	FN27	Capital works grants: sewerage	0	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.11a	FN32	Costs: operating water (NPR)	11701.23	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.12a	FN33	Costs: operating sewerage	8860.304	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.21	FN49	Costs: any other water	6043.853	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.22	FN50	Costs: any other sewerage	5772.122	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.7	FN74	Current replacement costs: fixed water assets	311356.3	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.8	FN75	Current replacement costs: fixed sewerage assets	227317.1	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.13	FN76	Costs: maintenance water	5427.244	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.14	FN77	Costs: maintenance sewerage	6375.948	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.15	FN78	Current cost depreciation: water	5634.628	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.16	FN79	Current cost depreciation: sewerage	4589.946	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.17	FN80	Previous 5 year average annual renewals expenditure: water	543	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.18	FN81	Previous 5 year average annual renewals expenditure: sewerage	2644	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.19	FN82	Forecast 5 year average annual renewals expenditure: water	4552	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.20	FN83	Forecast 5 year average annual renewals expenditure: sewerage	2649	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG3.5	FN9	Nominal written down replacement cost: fixed water assets	138287.8	\$,000	
2023	1375 Whitsunday Regional Council WSP-wide	QG4.1(val PR3		Fixed charge: water value	652	\$/annum	
2023	1375 Whitsunday Regional Council WSP-wide	QG4.2(val PR31		Fixed charge: sewerage value	900	\$/annum	
2023	1375 Whitsunday Regional Council WSP-wide	QG4.2(text PR40		Fixed charge: sewerage description	Charge by F Text		
2023	1375 Whitsunday Regional Council WSP-wide	QG4.3	PR47	Annual bill based on 200kL/a: water+sewerage	1784	\$	
2023	1375 Whitsunday Regional Council WSP-wide	QG4.4	PR48	Typical residential bill: water+sewerage	1914.52	\$	
2023	1375 Whitsunday Regional Council WSP-wide	QG4.1(text PR5		Fixed charge: water description	charge by p Text		
2023	1375 Whitsunday Regional Council WSP-wide	QG1.8	WA1	Volume water sourced: surface water	5070.9	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.9a	WA2	Volume water sourced: groundwater	1676.5	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.5	WA201	Maximum daily demand	24.2	ML/day	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.21	WA223	Volume all water imported: internal and external	1386.7	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.22	WA224	Volume all water exported: internal and external	1386.7	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.6a	WA225	Volume potable water produced at a water treatment plant	6646.8	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.11	WA26	Volume recycled sewage supplied: all	313.7	ML	

year	scheme ic scheme	kpi code	swim cod	indicator title	value	units	comments
2023	1375 Whitsunday Regional Council WSP-wide	QG1.17a	WA32	Volume potable water supplied: residential	3383.4	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.18a	WA34	Volume potable water supplied: non-residential	2270.8	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.10	WA61	Volume water sourced: desalination marine water	0	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.12	WA7	Volume water sourced: all	8447.8	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.17b	WA91	Volume raw-PT water supplied: residential	NR	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	NR	ML	
2023	1375 Whitsunday Regional Council WSP-wide	QG1.20	WF1	Total full-time equivalent water+sewerage employees	71	FTEs	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.10c	WS13	Water restriction duration: Level 2	365	days	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	no	yes/no	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
2023	1375 Whitsunday Regional Council WSP-wide	QG2.3	WS3	Available contingency supplies	yes	yes/no	