




# Drinking Water Quality Management DWQMP – Annual Report

2022-2023

Whitsunday Regional Council

Service Provider No.: 501

Author: Kerrie Pearson  
Environmental & Laboratory Coordinator  
Date: 15 December 2023




## TABLE OF CONTENTS

<b>Glossary of Terms</b> .....	<b>3</b>
<b>Introduction</b> .....	<b>4</b>
<b>1. Overview of Operations</b> .....	<b>5</b>
<b>2. DWQMP Implementation</b> .....	<b>6</b>
2.1 Implementing the Risk Management Improvement Program.....	6
2.2 The Monitoring Program.....	7
2.3 Amendments made to the DWQMP .....	7
<b>3. Compliance with Water Quality Criteria</b> .....	<b>7</b>
3.1 Chemical.....	7
3.2 E. coli .....	7
3.3 Fluoride .....	7
<b>4. Notifications to the Regulator</b> .....	<b>8</b>
<b>5. Customer Complaints Related to Water Quality</b> .....	<b>8</b>
5.1 Suspected Illness .....	8
5.2 Discoloured Water .....	8
5.3 Taste and Odour.....	8
<b>6. DWQMP Review</b> .....	<b>9</b>
<b>Appendix A – Summary of Compliance with Water Quality Criteria</b> .....	<b>10</b>
<b>Appendix B – Implementation of the DWQMP Risk Management Improvement Program</b> .....	<b>17</b>

# Glossary of Terms

ADWG 2011	Australian Drinking Water Guidelines (2011). Published by the National Health and Medical Research Council of Australia
<i>E. coli</i>	<i>Escherichia coli</i> , a bacterium which is considered to indicate the presence of faecal contamination and therefore potential health risk
HACCP	Hazard Analysis and Critical Control Points certification for protecting drinking water quality
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
MPN/100mL	Most probable number per 100 millilitres
CFU/100mL	Colony forming units per 100 millilitres
<	Less than
>	Greater than

Date	Report	Author	Reviewed By	Authorised by COO
15/12/2023	Annual Report	Kerrie Pearson	Paul Sandbek	Troy Pettiford 

# Introduction

This report documents the performance of Whitsunday Regional Council's drinking water service with respect to water quality and performance in implementing the actions detailed in the DWQMP as required under the *Water Supply (Safety and Reliability) Act 2008* (the Act).

The report assists the Regulator to determine whether the approved DWQMP and any approval conditions have been complied with and provides a mechanism for providers to report publicly on their performance in managing drinking water quality.

Whitsunday Regional Council is operating under an approved DWQMP to ensure consistent supply of safe quality drinking water in order to protect public health. This is done through proactive identification and minimisation of public health related risks associated with drinking water.

It has been prepared in accordance with the *Guideline for the preparation, review and audit of Drinking Water Quality Management Plans, Version 3* published by the Department of Regional Development, Manufacturing and Water, Queensland, October 2022 accessible at [www.business.qld.gov.au](http://www.business.qld.gov.au).

# 1. Overview of Operations

Water and wastewater is managed within Whitsunday Regional Council by a separate business unit “Whitsunday Water” since July 2015.

Whitsunday Water maintains and operates 4 water treatment plants, supplying water to a seasonally fluctuating population of over 35 000 people, including residential, commercial, tourism and industrial customers.

Scheme	Communities Served	Population served	Source	Treatment	Treatment Capacity, ML/day
Bowen	Bowen, Brisk Bay, Merinda	10400 (5200 connections)	Sub-surface / open water intake in the Proserpine River	Conventional Flocculation with lamella plate settling and Dual media filtration. Disinfected with Sodium Hypochlorite.	16.5 (Av 7.0)
Collinsville	Collinsville, Scottsville	1700 (1200 connections)	Bowen River Weir, from Eungella Dam (Sunwater)	Conventional Flocculation and filtration. Disinfected with Sodium Hypochlorite.	6 {Av 2.2}
Proserpine	Proserpine, Mt Julian (supplies Cannonvale/Airlie Beach)	4200 (2000 connections)	Aquifer bores, supplemented from Peter Faust Dam	Conventional Flocculation with Dual media filtration. Disinfected with Sodium Hypochlorite.	14 (Av 5.2)
Coastal	Cannonvale, Airlie Beach, Mt Julian, Jubilee Pocket	14600 (6500 connections)	Aquifer bores	Conventional Flocculation with Dual media filtration. Disinfected with Sodium Hypochlorite.	9.6 (Av 3.8)

*Table 1- Drinking Water Supplies*

Major changes in recent years include:

- Bulk supply pipeline – replaced existing 225 bulk water supply pipeline from Proserpine WTP to Coastal WTP with a 559 diameter pipe; new pump station to pump through the new pipeline; redirect Bore 10 from Coastal to Proserpine WTP. Completed.
- Cannon Valley Reservoirs – Constructed 2 new 12ML reservoirs; redirecting water from the new bulk supply pipeline to the new reservoirs only, with the rest of the network then being gravity fed from the Cannon Valley Reservoirs. The reservoirs construction has been completed but they are not yet online.
- Replacement of the existing 5 low lift pumps at the Bowen Water treatment Plant. Underway.
- New Proserpine River open water intake pump/structure for Bowen Water treatment Plant including replacement of the existing High lift pump station building switchboard to incorporate new pumps and open water tank. Design underway.
- Construction of additional raw water production bores to improve water reliability, water security, and to accommodate growth of the Coastal and Proserpine water catchments. Investigation and testing underway.
- Replacement of the existing pumps at the coastal water treatment plant to enable pumping to the new Cannon Valley reservoirs. Underway.
- Cannonvale water network augmentation project – to construct various trunk water mains and interconnecting links to optimise the utilisation of the existing reservoirs and partition the network. Underway.

- Cannonvale reservoir reconfiguration to allow refurbishment, repair and reconfigure its inlet and outlet. This can only take place after the new Cannon Valley reservoirs are on-line.

These will be included in future amendments of the DWQMP.

## 2. DWQMP Implementation

Water quality has been ensured by the implementation of safeguards and barriers identified in the DWQMP. Water quality in all areas has been kept to high standards with the implementation of sampling regimes, maintenance schedules and hazard identifications highlighted in the DWQMP.

### 2.1 Implementing the Risk Management Improvement Program

Refer to Appendix B for a summary of progress in implementing each of the Improvement Program actions.

All risk management improvement programs outlined in the DWQMP are being or have been implemented or are part of an ongoing maintenance strategy.

Items in the Risk Management Improvement Plan (RMIP) that have been Updated include

- Bowen open water intake – 2023 - Civil works now at concept stage. Preliminary works commenced, works progressing. Low lift pumps in place and operational.
- Proserpine Turbidity Analysers install and commissioning completed – standardisation across WIM alliance region.
- Collinsville water treatment plant - Secondary control completed on each filter to enable plant shutdown
- Storage reservoir works
  - Collinsville, Miller St – completed.
  - Collinsville, Mt Devlin - RPEQ certified inspection identified additional works to meet regulations & specs. Works tendered to replace roof, vermin proofing and repairs up to required specs. Completion by June 2024
  - Bowen, 12ML - Reroofing, stairs and roof access. Completion by June 2025
  - Bowen, 3ML - Roof replacement, roof & stair access & leak detection and repair. Completion by June 2025
  - Cannonvale - Structural inspection and subsequent repair, dependent on when Cannon Valley reservoirs are on-line. Completion by June 2026
  - Shute Harbour (Mt Roper) - access fencing. Completion by June 2025
- Proserpine Bores – Bore investigation underway – drilling for testing bores midway through completion.
- Collinsville Solar Project – Nearing completion. Solar Array installed, awaiting connection expected early 2024.
- Site security – Working with Facilities on CCTV and Slide gates/boom gates
- Cybersecurity - ongoing

## 2.2 The Monitoring Program

Operational monitoring and Verification monitoring programs have continued unchanged throughout the year.

## 2.3 Amendments made to the DWQMP

Version 3 of the DWQMP was approved in December 2021.

A further amendment (Version 3.1) was made in April 2022, which was rejected in November 2022 after a Show Cause Notice in September 2022.

A review of the DWQMP (new version 3.1) was conducted and submitted with an amendment application in October 2023. Outcome is pending.

The Approved DWQMP as at 30 June 2023 is Version 3, approved in December 2021.

# 3. Compliance with Water Quality Criteria

The water quality criteria mean health guideline values in the most current Australian Drinking Water Guidelines, as well as the standards in the Public Health Regulation 2005.

A summary of water quality characteristics for each scheme is contained in Appendix A.

## 3.1 Chemical

All samples taken during this financial year met the recommended health values in the Australian Drinking Water Guidelines.

There were 2 in-house Manganese values at Bowen that were above the aesthetic value of 0.1 mg/L. These were both the reticulated and treated sample from the same day, 24 August 2022. The in-house results did not correlate with the external results for August at below detection (<0.001 mg/L).

An in-house Aluminium value at Proserpine was above the aesthetic limit at 0.26 mg/L on 30 June 2023. The external samples from June 2023, with results of 0.091 and 0.14 mg/L for the reticulated and treated samples respectively, did not correlate with the in-house result.

Chlorate was detected again in Bowen Treated and Reticulated water in January and February 2023, respectively.

## 3.2 E. coli

There were no detections of E.coli for the 2022-23 financial year.

## 3.3 Fluoride

Fluoride is not added to water within the Whitsunday Regional Council area, so levels detected are natural background levels.

## 4. Notifications to the Regulator

The only notification made this year was involving a dirty water event at Collinsville over the weekend of 26 and 27 November 2022. Storm (electrical) events had disabled the Raw Water high Turbidity alarm. This allowed dirty water through the process into the Clear Water Storage (CWS) and may have been released to the reservoir. Reservoirs and the reticulation system were checked over the next few days with no indication that the dirty water had passed through to the reticulation system. All Turbidity results were below 2 NTU, all bacteriological results were <1 cfu/100mL. Until further actions can be completed the plant will not be run unmanned during the wet season. Other further actions include Dynamic dosing of raw water linked to turbidity, discussion with Sunwater about possibility of a turbidity meter at the Turkey nest and project plan for some installation works that have been delayed previously. The incident was closed in April 2023.

Refer to Incident DWI-501-22-09970.

## 5. Customer Complaints Related to Water Quality

Whitsunday Regional Council is required to report on the number of complaints, general details of complaints, and the responses undertaken.

Throughout the year the following complaints about water quality were received:

	Suspected Illness	Dirty water	Taste and odour	Total
Bowen	0	7	1	8
Coastal	0	1	3	4
Collinsville	0	0	0	0
Proserpine	0	1	0	1
Total	0	9	4	13

Table 2 – Complaints about water quality

### 5.1 Suspected Illness

There were no suspected illness complaints attributed to potable water.

### 5.2 Discoloured Water

The dirty water complaints in the Bowen area during the 2022-23 year were not related in either location, timing or source characteristics. For each instance the line was flushed to achieve clear water and no further action was required.

The dirty water complaints in the Coastal and Proserpine areas were, in each case, a localised issue and was flushed to achieve clear water. No further action was required.

### 5.3 Taste and Odour

The taste and odour complaints in the Bowen and Coastal areas were determined to be unsubstantiated and no further action was required other than flushing in some cases.



## 6. DWQMP Review

There was no official review of the DWQMP completed in the 2022-2023 year. A review is due 4 October 2023.

An amendment application, for version 3.1, was submitted in April 2022 and in September 2022 a Show Cause Notice was issued inviting Council to make submissions as to why it should not be directed to amend its approved DWQMP in a stated way. The submission was made by Council and the amendment application was not agreed to in November 2022. As such, the plan approved in December 2021, Version 3, is still the current version. Council sought input to ensure compliance with the regulatory requirements prior to submission of the review and amendment in October 2023.

Full details of the 2023 review will be included in the 2023-2024 report.

# Appendix A – Summary of Compliance with Water Quality Criteria

The results from the verification monitoring program have been compared against the levels of the water quality criteria specified by the Regulator in the *Water Quality and Reporting Guideline for a Drinking Water Service*.

Verification monitoring was carried out as per the program stated in the DWQMP.

A summary of water quality characteristics for each scheme are contained in the following tables.

Table 3a - Verification monitoring results - Bowen Scheme Potable Water

	Parameter	Unit of Measure	LOR	No. Samples		ADWG Aesthetic (Health) Guideline	No. of samples exceeding water quality criteria	Minimum Result	Maximum Result	Average of Results	95th Percentile	Comment
				to be collected from Approved Plan	Actual Total Samples Collected							
In House Test Results	pH	mg/L	0.1	104	406	406	6.5-8.5	0	7.0	7.8	7.4	
	Turbidity	NTU	0.01	104	405	405	5	0	0.02	0.55	0.10	
	Conductivity	µS/cm	1		144	144			300	498	397	
	Colour	Pt/Co	1	104	406	289	15	0	0	6	0.9	
	Free chlorine residual	mg/L	0.1		405	405			0.25	3.73	1.77	
	Total chlorine residual	mg/L	0.1		96	96			0.5	4.1	2.10	
	Alkalinity	mg/L	0.1	104	143	143			45	105	84	
	Total hardness	mg/L	0.1	104	143	143	200	0	56	120	85	
	Iron	mg/L	0.01	104	406	393	0.3	0	0.0	0.04	0.017	
	Manganese	mg/L	0.001	104	406	391	0.1 (0.5)	2	0.000	0.139	0.005	
Aluminium	mg/L	0.001	104	406	406	0.2	0	0.008	0.058	0.021		
NATA Lab Results	pH	mg/L	0.1	24	23	23	6.5-8.5	0	6.81	7.6	7.1	7.4
	Turbidity	NTU	1	24	23	0	5	0	<1	<1	<1	<1
	Colour	Pt/Co	1	24	23	0	15	0	<1	<1	<1	<1
	Conductivity	µS/cm	5	24	23	23			340	520	425	499
	Alkalinity	mg/L	5	24	23	23			72	97	82	97
	Total hardness	mg/L	5	24	23	23	200	0	66	102	86	101
	Total dissolved solids	mg/L	10	24	23	23		0	190	280	230	269
	Chloride	mg/L	2	24	23	23	250	0	54	88	71.6	85.0
	Sulphate	mg/L	2	24	23	23	250 (500)	0	11	17	13.5	16.9
	Fluoride	mg/L	0.05	24	23	23	(1.5)	0	0.08	0.12	0.10	0.12
	Nitrate	mg/L	0.05	24	23	21	(50)	0	0.05	0.53	0.21	0.44
	Silica	mg/L	5	24	23	23	80	0	13	16	14.5	16.0
	Sodium	mg/L	0.05	24	23	23	180	0	42	62	49.7	58.9
	Potassium	mg/L	0.05	24	23	23			2.4	3.6	2.8	3.5
	Calcium	mg/L	0.05	24	23	23			14	23	18.8	22.9
	Magnesium	mg/L	0.05	24	23	23			7.6	11	9.4	11.0
	Chlorate	mg/L	0.01	24	23	23			0.20	0.83	0.46	0.77
	Aluminium	mg/L	0.01	24	23	23	0.2	0	0.01	0.046	0.025	0.043
	Antimony	mg/L	0.0001	24	23	0	(0.003)	0	<0.0001	<0.0001	<0.0001	<0.0001
	Arsenic	mg/L	0.0001	24	23	23	(0.01)	0	0.0002	0.0005	0.0003	0.0005
	Barium	mg/L	0.001	24	23	22	(2)	0	0.04	0.06	0.047	0.058
	Beryllium	mg/L	0.0001	24	23	0	(0.06)	0	<0.0001	<0.0001	<0.0001	<0.0001
	Boron	mg/L	0.001	24	23	23	(4.0)	0	0.026	0.035	0.030	0.035
	Cadmium	mg/L	0.0001	24	23	0	(0.002)	0	<0.0001	<0.0001	<0.0001	<0.0001
	Chromium	mg/L	0.0001	24	23	6	(0.05)	0	0.0001	0.0001	0.0001	0.0001
	Cobalt	mg/L	0.0001	24	23	0			<0.0001	<0.0001	<0.0001	<0.0001
	Copper	mg/L	0.001	24	23	23	1 (2)	0	0.004	0.12	0.0329	0.0647
	Iron	mg/L	0.005	24	23	9	0.3	0	0.006	0.016	0.0107	0.0156
	Lead	mg/L	0.0001	24	23	20	(0.01)	0	0.0001	0.0018	0.0005	0.0015
	Mercury	mg/L	0.0001	24	23	0	(0.001)	0	<0.0001	<0.0001	<0.0001	<0.0001
	Manganese	mg/L	0.001	24	23	23	0.1 (0.5)	0	0.0001	0.031	0.0037	0.0179
	Molybdenum	mg/L	0.0001	24	23	23	(0.05)	0	0.0002	0.0004	0.0003	0.0004
	Nickel	mg/L	0.0001	24	23	22	(0.02)	0	0.0001	0.0005	0.0003	0.0004
	Selenium	mg/L	0.0001	24	23	0	(0.01)	0	<0.0001	<0.0001	<0.0001	<0.0001
	Silver	mg/L	0.001	24	23	0	(0.1)	0	<0.001	<0.001	<0.001	<0.001
	Strontium	mg/L	0.01	24	23	23			0.15	0.26	0.203	0.249
	Thallium	mg/L	0.0001	24	23	0			<0.0001	<0.0001	<0.0001	<0.0001
	Tin	mg/L	0.0001	24	23	3			0.0001	0.0043	0.0016	0.0039
	Titanium	mg/L	0.001	24	23	0			<0.001	<0.001	<0.001	<0.001
	Uranium	mg/L	0.0001	24	23	0	(0.017)	0	<0.0001	<0.0001	<0.0001	<0.0001
	Vanadium	mg/L	0.0001	24	23	19			0.0001	0.0003	0.0002	0.0002
	Zinc	mg/L	0.001	24	23	23	3	0	0.002	0.02	0.0063	0.0138
	Chloroform	µg/L	1	24	23	23			0	20.0	96.0	43.1
	Bromodichloro methane	µg/L	1	24	23	23			0	26.0	61.0	37.4
	Dibromochloro methane	µg/L	1	24	23	23			0	16.0	34.0	24.7
	Bromoform	µg/L	1	24	23	23			0	2.0	5.0	3.1
Total THMs	µg/L	1	24	23	23	(250)	0	70.0	190.0	107.5		
PFOS + PFHxS	µg/L	0.005	8	8	0	0.07	0	<0.005	<0.005	<0.005		
Methyl Isoborneol	ng/L	1	2	5	1			<2	3	<2		
Geosmin	ng/L	1	2	5	3			<2	6	2.6		
<b>Pesticide Residues -</b>												
Dalapon (2,2-DPA)	µg/L	0.2	2	2	2	(500)	0	0.7	2.1	1.4	Reticulated & Treated Refer QHFSS SSP0083684	
Desethyl Atrazine	µg/L	0.01	2	2	0	20	0	<0.01	<0.01	<0.01		
Atrazine, 2-hydroxyl	µg/L	0.01	2	2	2	200	0	0.01	0.01	0.01		
Metolachlor	µg/L	0.02	2	2	0	(300)	0	<0.02	<0.02	<0.02		
Imazapic	µg/L	0.01	2	2	0	(1000)	0	<0.01	<0.01	<0.01		
Triclopyr	µg/L	0.07	2	2	0	(0.02)	0	<0.07	<0.07	<0.07		
Hexazinone	µg/L	0.01	2	2	0	(0.4)	0	<0.01	<0.01	<0.01		
Others detected:-	µg/L											

Table 3b - Verification monitoring results - Coastal Scheme Potable Water

Parameter	Unit of Measure	LOR	No. Samples to be collected from Approved Plan		Actual Total Samples Collected	No. Samples in which parameter was detected	ADW/G Aesthetic (Health) Guideline	No. of samples exceeding water quality criteria	Minimum Result	Maximum Result	Average of Results	95th Percentile	Comment
			104	104									
In House Test Results	pH	mg/L	0.1	104	381	381	6.5-8.5	0	7.1	8.5	7.4		
	Turbidity	NTU	0.01	104	382	382	5	0	0.06	0.201	0.11		
	Conductivity	µS/cm	1		110	110			235	984	513		
	Colour	Pt/Co	1	104	383	68	15	0	0	2	0.2		
	Free chlorine residual	mg/L	0.1		379	379			0.28	1.99	1.20		
	Total chlorine residual	mg/L	0.1		64	64			0.92	2.06	1.42		
	Alkalinity	mg/L	0.1	104	111	111			59	129	104		
	Total hardness	mg/L	0.1	104	111	111	200	0	1	160	118		
	Iron	mg/L	0.01	104	377	342	0.3	0	0	0.07	0.01		
	Manganese	mg/L	0.001	104	382	313	0.1 (0.5)	0	0	0.069	0.011		
	Aluminium	mg/L	0.001	104	379	379	0.2	0	0.008	0.161	0.052		
NATA Lab Results	pH	mg/L	0.1	24	24	24	6.5-8.5	0	7.0	7.9	7.4	7.7	
	Turbidity	NTU	1	24	24	0	5	0	<1	<1	<1	<1	
	Colour	Pt/Co	1	24	24	0	15	0	<1	<1	<1	<1	
	Conductivity	µS/cm	5	24	24	24			450	640	523	570	
	Alkalinity	mg/L	5	24	24	24			84	110	97	109	
	Total hardness	mg/L	5	24	24	24	200	0	105	147	119	138	
	Total dissolved solids	mg/L	10	24	24	24		0	270	360	306	330	
	Chloride	mg/L	2	24	24	24	250	0	68	130	91.2	110.0	
	Sulphate	mg/L	2	24	24	24	250 (500)	0	6.4	17	11.5	14.9	
	Fluoride	mg/L	0.05	24	24	24	(1.5)	0	0.08	0.12	0.10	0.12	
	Nitrate	mg/L	0.05	24	24	24	(50)	0	4.8	8.4	6.98	8.19	
	Silica	mg/L	5	24	24	24	80	0	35	49	40.58	46.70	
	Sodium	mg/L	0.05	24	24	24	180	0	48	66	56.21	61.85	
	Potassium	mg/L	0.05	24	24	24			1.1	1.9	1.41	1.80	
	Calcium	mg/L	0.05	24	24	24			22	30	24.83	28.85	
	Magnesium	mg/L	0.05	24	24	24			12	18	14.00	16.00	
	Chlorate	mg/L	0.01	24	24	24			0.09	0.34	0.224	0.330	
	Aluminium	mg/L	0.01	24	24	24	0.2	0	0.038	0.078	0.059	0.077	
	Antimony	mg/L	0.0001	24	24	0	(0.003)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Arsenic	mg/L	0.0001	24	24	24	(0.01)	0	0.0002	0.0004	0.00027	0.00039	
	Barium	mg/L	0.001	24	24	24	(2)	0	0.027	0.043	0.0330	0.0410	
	Beryllium	mg/L	0.0001	24	24	0	(0.06)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Boron	mg/L	0.001	24	24	24	(4.0)	0	0.022	0.032	0.0255	0.0290	
	Cadmium	mg/L	0.0001	24	24	0	(0.002)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Chromium	mg/L	0.0001	24	24	1	(0.05)	0	0.0001	0.0001	0.0001	0.0001	
	Cobalt	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Copper	mg/L	0.001	24	24	12	1 (2)	0	0.001	0.005	0.0028	0.0050	
	Iron	mg/L	0.005	24	24	5	0.3	0	0.005	0.008	0.0066	0.0078	
	Lead	mg/L	0.0001	24	24	12	(0.01)	0	0.0001	0.0004	0.00023	0.00040	
	Mercury	mg/L	0.0001	24	24	0	(0.001)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Manganese	mg/L	0.001	24	24	24	0.1 (0.5)	0	0.0004	0.0055	0.0013	0.0029	
	Molybdenum	mg/L	0.0001	24	24	24	(0.05)	0	0.0002	0.0003	0.0002	0.0003	
	Nickel	mg/L	0.0001	24	24	11	(0.02)	0	0.0001	0.0005	0.0002	0.0004	
	Selenium	mg/L	0.0001	24	24	22	(0.01)	0	0.0001	0.0003	0.00020	0.00030	
	Silver	mg/L	0.001	24	24	0	(0.1)	0	<0.001	<0.001	<0.001	<0.001	
	Strontium	mg/L	0.01	24	24	24			0.24	0.39	0.315	0.377	
	Thallium	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Tin	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Titanium	mg/L	0.001	24	24	0			<0.001	<0.001	<0.001	<0.001	
	Uranium	mg/L	0.0001	24	24	6	(0.017)	0	0.0001	0.0001	0.00010	0.00010	
	Vanadium	mg/L	0.0001	24	24	24			0.0005	0.0025	0.0015	0.0024	
	Zinc	mg/L	0.001	24	24	15	3	0	0.001	0.024	0.0069	0.0198	
	Chloroform	µg/L	1	24	24	24			0	2.0	8.0	3.8	
	Bromodichloro methane	µg/L	1	24	24	24			0	6.0	20.0	11.3	
	Dibromochloro methane	µg/L	1	24	24	24			0	16.0	34.0	22.5	
	Bromoform	µg/L	1	24	24	24			0	9.0	22.0	13.7	
	Total THMs	µg/L	1	24	24	24	(250)	0	36.0	79.0	51.3		
PFOS + PFHxS	µg/L	0.005	8	8	0	0.07	0	<0.005	<0.005	<0.005		6:2 FTS Treated Nov 2022	
Methyl Isoborneol	ng/L	1	2	2	0			0	<2	<2	<2		
Geosmin	ng/L	1	2	2	0			0	<2	<2	<2		
Pesticide Residues -	Dalapon (2,2-DPA)	µg/L	0.2	2	2	0	(500)	0	<0.2	<0.2	<0.2		Reticulated & Treated Refer QHFSS SSP0083684
	Desethyl Atrazine	µg/L	0.01	2	2	0	20	0	<0.01	<0.01	<0.01		
	Atrazine, 2-hydroxyl	µg/L	0.01	2	2	2	200	0	0.01	0.03	0.02		
	Metolachlor	µg/L	0.02	2	2	0	(300)	0	<0.02	<0.02	<0.02		
	Imazapic	µg/L	0.01	2	2	0	(1000)	0	<0.01	<0.01	<0.01		
	Triclopyr	µg/L	0.07	2	2	0	(0.02)	0	<0.07	<0.07	<0.07		
	Hexazinone	µg/L	0.01	2	2	1	(0.4)	0	0.01	0.01	0.01		
	Others detected:-	µg/L											

Table 3c - Verification monitoring results - Collinsville Scheme Potable Water

Parameter	Unit of Measure	LOR	No. Samples to be collected from Approved Plan		Actual Total Samples Collected	No. Samples in which parameter was detected	ADWG Aesthetic (Health) Guideline	No. of samples exceeding water quality criteria	Minimum Result	Maximum Result	Average of Results	95th Percentile	Comment
			104	104									
In House Test Results	pH	mg/L	0.1	104	412	412	6.5-8.5	0	6.76	7.87	7.4		
	Turbidity	NTU	0.01	104	411	411	5	0	0.05	1.12	0.16		
	Conductivity	µS/cm	1		150	150			113	250	167		
	Colour	Pt/Co	1	104	405	162	15	0	0	14	1.3		
	Free chlorine residual	mg/L	0.1		406	406			0.2	2.14	1.1		
	Total chlorine residual	mg/L	0.1		401	100			0.198	3.25	1.4		
	Alkalinity	mg/L	0.1	104	149	149			0.45	83	45		
	Total hardness	mg/L	0.1	104	0		200						
	Iron	mg/L	0.01	104	405	398	0.3	0	0	0.05	0.017		
	Manganese	mg/L	0.001	104	405	384	0.1 (0.5)	0	0	0.014	0.003		
	Aluminium	mg/L	0.001	104	412	412	0.2	0	0.008	0.266	0.020		
NATA Lab Results	pH	mg/L	0.1	24	24	24	6.5-8.5	0	6.6	7.3	6.9	7.2	
	Turbidity	NTU	1	24	24	0	5	0	<1	<1	<1	<1	
	Colour	Pt/Co	1	24	24	0	15	0	<1	<1	<1	<1	
	Conductivity	µS/cm	5	24	24	24			150	280	192	274	
	Alkalinity	mg/L	5	24	24	24			28	74	52	73	
	Total hardness	mg/L	5	24	24	24	200	0	38	77	54	76	
	Total dissolved solids	mg/L	10	24	24	24		0	92	170	116	166	
	Chloride	mg/L	2	24	24	24	250	0	12	21	16.8	20.9	
	Sulphate	mg/L	2	24	24	24	250 (500)	0	1.7	38	17.7	34.9	
	Fluoride	mg/L	0.05	24	24	24	(1.5)	0	0.03	0.08	0.053	0.080	
	Nitrate	mg/L	0.05	24	24	24	(50)	0	0.08	0.46	0.204	0.327	
	Silica	mg/L	5	24	24	24	80	0	10	17	14.2	16.9	
	Sodium	mg/L	0.05	24	24	24	180	0	12	25	15.7	23.1	
	Potassium	mg/L	0.05	24	24	24			0.93	2.1	1.40	2.00	
	Calcium	mg/L	0.05	24	24	24			9.8	20	13.8	20.0	
	Magnesium	mg/L	0.05	24	24	24			3.3	6.6	4.85	6.49	
	Chlorate	mg/L	0.01	24	24	24			0.13	0.36	0.218	0.344	
	Aluminium	mg/L	0.01	24	24	24	0.2	0	0.008	0.052	0.0208	0.0307	
	Antimony	mg/L	0.0001	24	24	0	(0.003)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Arsenic	mg/L	0.0001	24	24	17	(0.01)	0	0.0001	0.0003	0.00019	0.00030	
	Barium	mg/L	0.001	24	24	24	(2)	0	0.015	0.042	0.0229	0.0390	
	Beryllium	mg/L	0.0001	24	24	0	(0.06)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Boron	mg/L	0.001	24	24	24	(4.0)	0	0.011	0.18	0.023	0.023	
	Cadmium	mg/L	0.0001	24	24	0	(0.002)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Chromium	mg/L	0.0001	24	24	1	(0.05)	0	0.0002	0.0002	0.0002	0.0002	
	Cobalt	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Copper	mg/L	0.001	24	24	24	1 (2)	0	0.001	0.057	0.0105	0.0327	
	Iron	mg/L	0.005	24	24	12	0.3	0	0.005	0.029	0.0132	0.0263	
	Lead	mg/L	0.0001	24	24	10	(0.01)	0	0.0001	0.0002	0.00013	0.0002	
	Mercury	mg/L	0.0001	24	24	0	(0.001)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Manganese	mg/L	0.001	24	24	24	0.1 (0.5)	0	0.0002	0.0063	0.0015	0.0032	
	Molybdenum	mg/L	0.0001	24	24	24	(0.05)	0	0.0002	0.0006	0.0003	0.0006	
	Nickel	mg/L	0.0001	24	24	22	(0.02)	0	0.0001	0.0003	0.00021	0.00030	
	Selenium	mg/L	0.0001	24	24	0	(0.01)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Silver	mg/L	0.001	24	24	0	(0.1)	0	<0.001	<0.001	<0.001	<0.001	
	Strontium	mg/L	0.01	24	24	24			0.077	0.18	0.116	0.180	
	Thallium	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Tin	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Titanium	mg/L	0.001	24	24	0			<0.001	<0.001	<0.001	<0.001	
	Uranium	mg/L	0.0001	24	24	0	(0.017)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Vanadium	mg/L	0.0001	24	24	24			0.0005	0.0032	0.0016	0.0029	
	Zinc	mg/L	0.001	24	24	24	3	0	0.001	0.023	0.0075	0.0184	
	Chloroform	µg/L	1	24	24	24			0	8.0	62.0	28.8	
	Bromodichloro methane	µg/L	1	24	24	24			0	8.0	22.0	13.8	
	Dibromochloro methane	µg/L	1	24	24	24			0	2.0	8.0	5.0	
	Bromoform	µg/L	1	24	24	1			0	1.0	1.0	1.0	
	Total THMs	µg/L	1	24	24	24	(250)	0	21.0	90.0	47.8		
PFOS + PFHxS	µg/L	0.005	8	8	0	0.07	0	<0.005	<0.005	<0.005		Retic & Treated 6:2 FTS present Nov 2022	
Methyl Isoborneol	ng/L	1	2	2	0			0	<2	<2	<2		
Geosmin	ng/L	1	2	2	0			0	<2	<2	<2		
<b>Pesticide Residues -</b>													
Dalapon (2,2-DPA)	µg/L	0.2	2	2	2	(500)	0	0.2	0.5	0.4		Reticulated & Treated Refer QHFSS SSP0083684	
Desethyl Atrazine	µg/L	0.01	2	2	0	20	0	<0.01	<0.01	<0.01			
Atrazine, 2-hydroxyl	µg/L	0.01	2	2	0	200	0	<0.01	<0.01	<0.01			
Metolachlor	µg/L	0.02	2	2	0	(300)	0	<0.02	<0.02	<0.02			
Imazapic	µg/L	0.01	2	2	0	(1000)	0	<0.01	<0.01	<0.01			
Triclopyr	µg/L	0.07	2	2	0	(0.02)	0	<0.07	<0.07	<0.07			
Hexazinone	µg/L	0.01	2	2	0	(0.4)	0	<0.01	<0.01	<0.01			
Others detected:-	µg/L												

Table 3d - Verification monitoring results - Proserpine Scheme Potable Water

Parameter	Unit of Measure	LOR	No. Samples to be collected from Approved Plan		Actual Total Samples Collected	No. Samples in which parameter was detected	ADWG Aesthetic (Health) Guideline	No. of samples exceeding water quality criteria	Minimum Result	Maximum Result	Average of Results	95th Percentile	Comment
			104	104									
In House Test Results	pH	mg/L	0.1	104	390	390	6.5-8.5	0	7.1	7.9	7.6		
	Turbidity	NTU	0.01	104	390	390	5	0	0.05	0.70	0.10		
	Conductivity	µS/cm	1		124	124			420	703	499		
	Colour	Pt/Co	1	104	390	54	15	0	0	1.5	0.2		
	Free chlorine residual	mg/L	0.1		386	386			0.5	2.05	1.13		
	Total chlorine residual	mg/L	0.1		76	76			0.65	2.1	1.30		
	Alkalinity	mg/L	0.1	104	123	123			48.6	162.8	108		
	Total hardness	mg/L	0.1	104	121	121	200	0	15.2	158	108		
	Iron	mg/L	0.01	104	388	357	0.3	0	0	0.05	0.013		
	Manganese	mg/L	0.001	104	388	326	0.1 (0.5)	0	0	0.075	0.008		
Aluminium	mg/L	0.001	104	388	388	0.2	1	0.007	0.259	0.073			
NATA Lab Results	pH	mg/L	0.1	24	24	24	6.5-8.5	0	7.2	8.0	7.6	7.9	
	Turbidity	NTU	1	24	24	0	5	0	<1	<1	<1	<1	
	Colour	Pt/Co	1	24	24	0	15	0	<1	<1	<1	<1	
	Conductivity	µS/cm	5	24	24	24			430	520	488	519	
	Alkalinity	mg/L	5	24	24	24			98	120	108	120	
	Total hardness	mg/L	5	24	24	24	200	0	95	113	108	112	
	Total dissolved solids	mg/L	10	24	24	24		0	260	330	300.0	320.0	
	Chloride	mg/L	2	24	24	24	250	0	63	80	74.0	79.0	
	Sulphate	mg/L	2	24	24	24	250 (500)	0	12	20	14.7	18.9	
	Fluoride	mg/L	0.05	24	24	24	(1.5)	0	0.1	0.14	0.120	0.130	
	Nitrate	mg/L	0.05	24	24	24	(50)	0	4.4	8.9	7.29	8.69	
	Silica	mg/L	5	24	24	24	80	0	33	54	46.1	52.9	
	Sodium	mg/L	0.05	24	24	24	180	0	46	62	56.3	61.0	
	Potassium	mg/L	0.05	24	24	24			0.86	1.5	1.05	1.30	
	Calcium	mg/L	0.05	24	24	24			19	23	21.92	23.00	
	Magnesium	mg/L	0.05	24	24	24			12	14	13.13	14.00	
	Chlorate	mg/L	0.01	24	24	24			0.18	0.47	0.277	0.389	
	Aluminium	mg/L	0.01	24	24	24	0.2	0	0.006	0.16	0.083	0.149	
	Antimony	mg/L	0.0001	24	24	0	(0.003)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Arsenic	mg/L	0.0001	24	24	24	(0.01)	0	0.0002	0.0004	0.0003	0.0004	
	Barium	mg/L	0.001	24	24	24	(2)	0	0.022	0.031	0.026	0.030	
	Beryllium	mg/L	0.0001	24	24	0	(0.06)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Boron	mg/L	0.001	24	24	24	(4.0)	0	0.024	0.033	0.0269	0.0319	
	Cadmium	mg/L	0.0001	24	24	0	(0.002)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Chromium	mg/L	0.0001	24	24	1	(0.05)	0	0.0001	0.0001	0.0001	0.0001	
	Cobalt	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Copper	mg/L	0.001	24	24	12	1 (2)	0	0.001	0.003	0.0018	0.0030	
	Iron	mg/L	0.005	24	24	1	0.3	0	0.007	0.007	0.007	0.007	
	Lead	mg/L	0.0001	24	24	2	(0.01)	0	0.0001	0.0001	0.0001	0.0001	
	Mercury	mg/L	0.0001	24	24	0	(0.001)	0	<0.0001	<0.0001	<0.0001	<0.0001	
	Manganese	mg/L	0.001	24	24	24	0.1 (0.5)	0	0.0002	0.0031	0.00085	0.00218	
	Molybdenum	mg/L	0.0001	24	24	24	(0.05)	0	0.0002	0.0003	0.00021	0.00029	
	Nickel	mg/L	0.0001	24	24	10	(0.02)	0	0.0001	0.0016	0.00033	0.00097	
	Selenium	mg/L	0.0001	24	24	24	(0.01)	0	0.0002	0.0004	0.00032	0.00040	
	Silver	mg/L	0.001	24	24	0	(0.1)	0	<0.001	<0.001	<0.001	<0.001	
	Strontium	mg/L	0.01	24	24	24			0.24	0.31	0.285	0.300	
	Thallium	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Tin	mg/L	0.0001	24	24	0			<0.0001	<0.0001	<0.0001	<0.0001	
	Titanium	mg/L	0.001	24	24	0			<0.001	<0.001	<0.001	<0.001	
	Uranium	mg/L	0.0001	24	24	23	(0.017)	0	0.0001	0.0002	0.00013	0.00020	
	Vanadium	mg/L	0.0001	24	24	24			0.0015	0.0036	0.00259	0.00336	
	Zinc	mg/L	0.001	24	24	12	3	0	0.001	0.002	0.0016	0.0020	
	Chloroform	µg/L	1	24	24	21			0	1.0	11.0	3.0	
	Bromodichloro methane	µg/L	1	24	24	24			0	3.0	22.0	8.6	
	Dibromochloro methane	µg/L	1	24	24	24			0	8.0	34.0	18.0	
	Bromoform	µg/L	1	24	24	24			0	8.0	20.0	12.6	
	Total THMs	µg/L	1	24	24	24	(250)	0	22.0	80.0	42.0		
PFOS + PFHxS	µg/L	0.005	8	8	0	0.07	0	<0.005	<0.005	<0.005		Retic 6:2 FTS present Nov 2022, Feb 2023	
Methyl Isoborneol	ng/L	1	2	2	0			0	<2	<2	<2		
Geosmin	ng/L	1	2	2	0			0	<2	<2	<2		
<b>Pesticide Residues -</b>													
Dalapon (2,2-DPA)	µg/L	0.2	2	2	0	(500)	0	<0.2	<0.2	<0.2		Reticulated & Treated Refer QHFSS SSP0083684	
Desethyl Atrazine	µg/L	0.01	2	2	1	20	0	0.01	0.01	0.01			
Atrazine, 2-hydroxyl	µg/L	0.01	2	2	1	200	0	0.01	0.01	0.01			
Metolachlor	µg/L	0.02	2	2	2	(300)	0	0.01	0.02	0.02			
Imazapic	µg/L	0.01	2	2	0	(1000)	0	<0.01	<0.01	<0.01			
Triclopyr	µg/L	0.07	2	2	0	(0.02)	0	<0.07	<0.07	<0.07			
Hexazinone	µg/L	0.01	2	2	1	(0.4)	0	0.01	0.01	0.01			
Others detected:-	µg/L												

**Table 4 - Reticulation *E.coli* verification monitoring**

Drinking water scheme:	Year	Month	No. of samples from Approved Plan	No. of samples collected	No. of samples collected in which <i>E. coli</i> is detected (i.e. a failure)	No. of samples collected in previous 12 month period	No. of failures for previous 12 month period	% of samples that comply	Compliance with 98% annual value
Bowen Scheme	2022	July	21	22	0	256	0	100	YES
		Aug	21	24	0	263	0	100	YES
		Sept	21	21	0	262	0	100	YES
		Oct	21	24	0	265	0	100	YES
		Nov	21	21	0	262	0	100	YES
		Dec	21	21	0	265	0	100	YES
	2023	Jan	21	24	0	268	0	100	YES
		Feb	21	21	0	270	0	100	YES
		Mar	21	26	0	270	0	100	YES
		Apr	21	21	0	270	0	100	YES
		May	21	24	0	271	0	100	YES
		June	21	21	0	270	0	100	YES
Coastal Scheme	2022	July	20	20	0	237	0	100	YES
		Aug	20	22	0	239	0	100	YES
		Sept	20	19	0	235	0	100	YES
		Oct	20	19	0	234	0	100	YES
		Nov	20	26	0	240	0	100	YES
		Dec	20	20	0	260	0	100	YES
	2023	Jan	20	20	0	242	0	100	YES
		Feb	20	15	0	240	0	100	YES
		Mar	20	25	0	247	0	100	YES
		Apr	20	20	0	247	0	100	YES
		May	20	23	0	253	0	100	YES
		June	20	21	0	250	0	100	YES
Collinsville Scheme	2022	July	18	18	0	223	2	99.1	YES
		Aug	18	21	0	228	2	99.1	YES
		Sept	18	18	0	228	2	99.1	YES
		Oct	18	21	0	231	2	99.1	YES
		Nov	18	28	0	239	2	99.2	YES
		Dec	18	18	0	242	2	99.2	YES
	2023	Jan	18	23	0	247	2	99.2	YES
		Feb	18	18	0	250	2	99.2	YES
		Mar	18	18	0	245	2	99.2	YES
		Apr	18	18	0	240	0	100	YES
		May	18	21	0	240	0	100	YES
		June	18	18	0	240	0	100	YES
Proserpine Scheme	2022	July	18	19	0	244	0	100	YES
		Aug	18	23	0	245	0	100	YES
		Sept	18	19	0	245	0	100	YES
		Oct	18	19	0	245	0	100	YES
		Nov	18	24	0	247	0	100	YES
		Dec	18	19	0	245	0	100	YES
	2023	Jan	18	24	0	250	0	100	YES
		Feb	18	20	0	252	0	100	YES
		Mar	18	19	0	246	0	100	YES
		Apr	18	19	0	246	0	100	YES
		May	18	23	0	250	0	100	YES
		June	18	19	0	247	0	100	YES

<b>Table 5 - Raw Water Monitoring Results</b>					
Parameter	Unit	Bowen Raw	Coastal Raw	Collinsville Raw	Proserpine Raw
Date Sampled		16/05/2023	16/05/2023	23/05/2023	16/05/2023
Methyl Isoborneol (MIB)	ng/L	<2	<2	<2	<2
Geosmin	ng/L	<2	<2	<2	<2
Non Purgeable Organic Carbon	mg/L	3.9	1.3	1.7	0.9
Dissolved NPOC	mg/L	3.7	1.3	LA	0.7
Date Sampled		16/05/2023	16/05/2023	16/05/2023	16/05/2023
Total Alpha Activity	Bq/L	<0.1	<0.1	<0.1	<0.1
Total Beta Activity	Bq/L	<0.1	<0.1	<0.1	<0.1
K40 Corrected Beta Activity	Bq/L	<0.1	<0.1	<0.1	<0.1
<b>Herbicides -</b>					
Metolachlor	µg/L	<0.02	<0.02	<0.02	0.03
Bromacil	µg/L	<0.02	<0.02	<0.02	0.13
Desethyl Atrazine	µg/L	0.01	0.01	<0.01	0.01
Atrazine, 2-hydroxyl	µg/L	<0.01	0.03	<0.01	<0.01
Hexazinone	µg/L	<0.01	0.02	<0.01	<0.01

<b>Table 6 - Bowen Raw Water Blue Green Algae Results</b>		
<b>Bowen Raw Water Blue Green Algae (cells/mL)</b>		
16/08/2022	4110	
15/11/2022	60000	Toxins <0.03 µg/L
21/02/2023	118400	Toxins <0.03 µg/L
16/05/2023	8000	



# Appendix B – Implementation of the DWQMP Risk Management Improvement Program

APPENDIX B - Risk Management Improvement Plan											Completed	
											Ongoing	
											Lastest comments	
Scheme Component / Sub-component	Hazardous event	Hazard	Priority	Interim Action(s)	Short-term Action(s)	Long-term Action(s)	Original Target date/s	Revised Target Date	Cost	Responsibility	Actions Taken	
Catchment - Proserpine River	1	Inadequate Water Supply - Bowen WTP	Supply loss & pump damage	Medium	Monitor flows and pump efficiencies. Replace pump impellers. Start design work on options. <b>Completed</b>	Remove sand from around spears and rock gabling in 2018 <b>Completed</b>	- Open water intake, - major maintenance around spears (remove geofabric & rock repack)	- Nov 2018 - May 2019	<del>Aug 2019 (maintenance)</del> <del>June 2022</del> <del>Jun 2023</del> Jun 2024	Est \$800K for intake \$500K for river spear maint	Treatment Operations Manager, Planning & Assets Engineer, Capital Works Manager, <b>Principal Engineer (Treatment)</b>	Initial-Open water intake design work commenced and initial tender released. <b>Preliminary works commenced.</b> 2018-Open water intake utilising a diesel pump operational. Civil construction works delayed up to 3 years as tender prices significantly higher than anticipated. <b>2023 - Civil works now at concept stage, works progressing.</b> Maintenance done in 2018, will be carried out again 2019. 3 stage capital process-Building; electrical; mechanical; starting Jan 2022 Replacement of existing pumps underway <b>In place and operational.</b> Assessing electric pump to replace diesel pump - <b>Ongoing</b> Maintenance of spears - <b>ongoing</b> Future works - increase spear capacity, still in concept design, <b>open water intake &amp; options for bores beside river.</b>
Catchment - Proserpine Bores	30	Inadequate Water Supply - Proserpine WTP	Supply loss & pump damage	Medium	<b>Engaged subject matter expert to carry out investigation and design</b>	<b>Bore investigation underway</b>	New bores (and pump station) to replace Bore 1, 2, 3 - lower risk water - closer proximity to Proserpine WTP <b>- Investigate open water intake as a supply option</b>	2022-23	2024-25	Est \$2.5M	Planning & Assets Engineer	2018-Concept design completed <b>Pump Station complete, undergoing commissioning. Refer No. 29.</b> Planning for bores underway; funding application in process for construction of 4 bores (1 bore funded) Design phase underway on schedule; Capital works due for completion 23-24 <b>Bore 10 redirected</b>
WTP	32	Instrumentation Failure	Loss of online monitoring	Low			Replace Turbidity Analysers with HACH units as required.	<del>June 2023</del> Dec 2023			<b>Principal Engineer (Treatment)</b>	<b>Due to unavailability of service technician (COVID lockdowns) will change to service provider with local technicians.</b> Cabinet and meters delivered, installation scheduled by June 23 <b>Standardisation across region through WIM Alliance.</b>
Collinsville WTP	5	Filtration Failure	Turbidity etc.	Low		Turbidity Analysers at each Filter	Control system to have more control over plant	Short Term <del>July 2018</del> Long Term <del>July 2019</del> <del>Dec 2022</del> Dec 2023			Treatment Operations Manager <b>Principal Engineer (Treatment)</b>	Initial-Analysers received 2018-Turbidity analysers installed. SCADA control scheduled for completion September 2019. SCADA control delayed due to incorporation into Solar panel project with completion due end 2022. Further delays due to absences of key staff. Existing Radtel to stay with ClearScada overlays, there may be constraints on what can be done. <b>Secondary control completed on each filter to enable plant shutdown</b>
Collinsville WTP	33	Electrical components failure - <b>pump, power</b>	Loss of Supply			Collinsville Solar Project		Jun-22	Dec 2023	\$900K	<del>Treatment-Operations-Manager</del> <b>Capital Works Project Manager</b>	Solar energy project to run both Collinsville WTP and STP with electrical upgrades at both plants, incorporating SCADA control, generator will be incorporated. <b>No STP will be included at this stage.</b> Delayed due to absences of key staff (including Project Manager). <del>Initial project was simple, but has grown to include rewiring and existing transformer needs to be replaced (26-week wait)</del> <b>Scope revised to fit within scope and existing funding. No rewiring etc.</b> <b>In house project manager and superintendent employed to complete package of works.</b>

Storage Reservoirs	20	Human access to reservoirs	Bacterial, Viral and Protozoan contamination due to animal or human entry	High	Inspection of all reservoir roof structures, security and vermin proofing	Immediate minor repairs to identified issues where possible	Full asset check of all reservoir structures, vermin proofing material and site security, with asset list and mapping creation. Also preventative maintenance schedule created	Dec-15	Ongoing	Staff time + what ever tasks are required.	Treatment Operations Manager & field staff, Network Operations Managers	Initial-Inspections complete. Roof repairs done. Monthly Reservoir inspections commenced. Repairs to vermin proofing from cyclone Debbie required - Scheduled for October - December 2017. 2018-Ongoing External audit of all reservoirs scheduled for 2019 (including safety and security). Report will feed into the database for scheduling of works required. Inspections ongoing - Operators-water quality; Networks-structural/mechanical External audit money used for maintenance and audit carried out by our own staff. Remaining findings included into maintenance schedule. Repair works to commence on Mt Devlin reservoir.
Security	31	Cybersecurity	Breach into SCADA at WTP's or in Network	High		CCTV & Boom gates at plants. External Audit of all sites	Implement audit actions	Short Term-end 2019; Long Term 2020	Jun-24		Treatment Operations Manager; Network Operations Managers	2018-CCTV & Boomgates installation commenced. External audit scope devised. Site Safety - STPs completed. Business case to be developed for high risk water sites (eg Proserpine WTP as is a multi use depot) for electronic gates. Multiple locks are in use in some areas - to be removed. CCTV not working consistently, footage not available. Working with Facilities on CCTV Slide gates preferable to boom gates Cybersecurity - SCADA Strategy and 16 quick wins initiated. Ongoing. Completed (initial items)
Staff Training and Awareness	34	Staffing	Insufficient staffing redundancy	High	Quality over Quantity		Fully Trained operators for relief use at any site				Treatment Operations Manager	No redundancy staff available for periods of absence. Collinsville WTP - only available backup has experience but no qualifications. Replacement staff very difficult to get. Only Trainee not filled. Continuing with staff rotation program to enable staff multiskilling
Storage Reservoirs	35	Human access to reservoirs	Bacterial, Viral and Protozoan contamination due to animal or human entry	High			Repair works to reservoirs	Mt Devlin - June 2024 Bowen - June 2025 Cannonvale - June 2026 Shute Harbour - June 2025			Capital Works Project Manager	Collinsville, Miller St - completed Collinsville, Mt Devlin - RPEQ certified inspection identified additional works to meet regulations & specs. Works tendered to replace roof, vermin proofing and repairs up to required specs. Bowen, 12ML - Reroofing, stair and roof access Bowen, 3ML - Roof replacement, roof & stair access & leak detection and repair Cannonvale - Structural inspection and subsequent repair, dependent on Cannon Valley reservoirs on line. Shute Harbour (Mt Roper) - access fencing
Collinsville WTP	4	Contamination by Fresh Water Shellfish	Taste & Odour	Low	Shellfish removed as soon as observed. Regular inspections. Chlorination.	- PAC dosing initiated as required to remove taste and odour compounds			Ongoing	Operational cost as required	Operator	Initial-Ongoing maintenance; PAC dosing can be utilised to reduce taste and odour compounds Ongoing Complete Drain and clean of clarifier 2020 (travelling bridge also adjusted) Maintenance ongoing
Reticulation	6	Chlorine Overdose	Taste / Odour	Low	Sodium hypochlorite dosing based on flow rate in WTP. Online chlorine analysers at plant have high chlorine CCP alarm that initiates plant shutdown. Daily sampling undertaken.	Telemetry to be installed to new online instrumentation within the reticulation.	Investigate effect of closing down re-chlorination stations & installation of more online analysers at strategic locations around the region.	Jun-19	Jun-22	\$10K for telemetry on new analysers.	Treatment Operations Manager	Initial-Online chlorine residual analysers have been installed within the Bowen, Proserpine & Cannonvale reticulation. Extra (Auto) sodium hypochlorite monitoring & dosing equipment installed at Bowen reservoir & Flemington rd chlorinator. 2018-Bowen reservoir completed. Flemington Rd chlorinator to be decommissioned. Railway Rd (Merinda) dosing stations upgraded. Telemetry for all analysers scheduled for 2021-22. Southern reticulation network upgrade scheduled, See #29.

Reticulation	7	Chlorination failure / Loss of Residual / Chlorinator failure	Public health	High	Sodium hypochlorite dosing based on flow rate in WTP. Online chlorine analysers at plant have low chlorine CCP alarm that initiates plant shutdown. Daily sampling undertaken.	Telemetry to be installed to new online instrumentation within the reticulation.	Investigate effect of closing down re-chlorination stations & installation of more online analysers at strategic locations around the region.	Jul-19		\$10K for telemetry on new analysers.	Treatment Operations Manager	As per No. 6
Reticulation	9	Backflow	public health / Aesthetics	High	All RPZDs to be tested	RPZD testing schedule to be implemented with checks to ensure tests are completed in time. Faulty devices to be repaired or replaced.	Assets mapped and listed and annual preventative maintenance implemented into councils systems. Investigate if RPZ are present as part of meter assembly during	Nov-15	Nov-19	Staff time	Treatment Operations Manager, Trade Waste Coordinator, Network Operations Managers	Initial-Incomplete lists have been developed for Northern and Southern areas. Consolidating this role into a regional one through the trade waste coordinator. 2018-This role has moved back to Water Operations. Audit completed, lists to be compiled into the new Council system. Ongoing Maintenance plan underway
Reticulation	10	High flow (sediments mobilised, slimes detached)	Aesthetics / Suspended Solids / Taste, Odour & Colour	Medium	Flushing program	Pigging program	Pigging program		Ongoing	Staff time	Planning & Assets Engineer, Network Operations Managers	Initial-Pigging program underway 2018-Ongoing Includes bore mains. Ongoing
Reticulation	11	Slimes detaching	Aesthetics / Suspended Solids / Taste, Odour & Colour	Medium	Flushing program	Pigging program	Pigging program		Ongoing	Staff time	Planning & Assets Engineer, Network Operations Managers	Initial-Pigging program underway 2018-Ongoing Ongoing
Bowen - Proserpine main	17	Farmers over use of treated water	Water supply cut-off / Public health	High	Monitoring of usage and communication with farmers using WRWW treated water.	Future planning of use by farmers, with farmers	Farmers and state government to use alternatives to treated water.	tbc	Dec-16	Staff time	Planning & Assets Engineer	Initial-Only 1 user allocation still in effect 2018-Monitoring on other potential users.
Bowen - Proserpine main	18	Farmers contaminating Drinking water supply	Public health	Medium	Communication with Farmers	Farmers to be asked to create SOPs for their usage of supply	Council to review farmers SOPs & processes for turning water on/off & usage. Also farmers to eventually use alternatives to treated drinking water.	tbc	Dec-16	Staff time	Planning & Assets Engineer	Initial-Only 1 user allocation still in effect 2018-Monitoring on other potential users.
Storage Reservoirs	21	Animal Access to reservoirs.	Bacteria I, Viral and Protozoan contamination due to animal or human	High	Inspection of all reservoir roof structures, security and vermin proofing	Immediate minor repairs to identified issues where possible	Full asset check of all reservoir structures, vermin proofing material and site security, with asset list and mapping creation. Also preventative maintenance schedule created & implemented	Dec-15	Ongoing	Staff time + what ever tasks are required.	Treatment Operations Manager & field staff, Network Operations Managers	Initial-Inspections complete. Roof repairs done. Monthly Reservoir inspections commenced. Repairs to vermin proofing from cyclone Debby required - Scheduled for October - December 2017. 2018-Ongoing Ongoing
Storage Reservoirs	22	Short circuiting of reservoirs	Bacteria I, Viral, Protozoa	Medium	Reservoirs to be operated to ensure turnover (when network allows).	Possible pipework changes	Install mixers if appropriate. Installing sample taps at reservoirs to enable monthly sampling.	2017-18	Ongoing Monitoring	Staff time	Treatment Operations Manager.	Initial-Reservoirs appear to have appropriate mixing via operational level controls. Regular sampling to ensure residual maintained carried out each month. 2018-Ongoing Ongoing

Security	25	Water quality	Water quality	High			In-depth Risk assessment and control measures to improve security at drinking water supply system sites and WTPs	Jun-16	Ongoing		Treatment Operations Manager, Network Operations Managers, Team Leaders	Initial-Risk assessments contained within DWQMP. Monthly Reservoir checks improve security on site. 2018-Ongoing Ongoing
Operation and Maintenance Procedures	26			High	Draft set of procedures to be reviewed and updated.	Additional procedures required identified, drafted, reviewed and implemented	Regular review	Dec-15	Ongoing	Staff time	Treatment Operations Manager; Network Operations Managers, Field Staff, Environmental Management Coordinator	Initial-A list of procedures (included in DWQMP) will be reviewed on 2 yearly basis. Further procedures identified in risk assessments will be developed as required. 2018-Ongoing Ongoing
Staff Training and Awareness	27	Staff training and awareness	Staff training and awareness	High			Implement training and awareness workshops once management plan approved in toolbox talks. Assess training need through internal audits and general feedback. KPI toolbox talk, updated ADWG related toolbox talks	Dec-15	Ongoing	Staff time	Treatment Operations Manager; Senior Staff, Field Staff, Environmental Management Coordinator	Initial-Gap analysis training conducted in September 2017 to certify operators under new national training package (NWP15). Refresher may be required for new staff, and new staff will also be updated under the new training package. 2018-Ongoing Ongoing
Customer Awareness Processes	28	Customer awareness	Customer awareness	Medium			Customer process definition and provide details to customer in customer service standards on levels of service they can expect.	Dec-15	Ongoing	Staff time	Treatment Operations Manager; Environmental Management Coordinator, Website client liaison.	Initial-Complete. Updated standards uploaded onto Whitsunday Regional Councils website as required. 2018-Ongoing Ongoing
WTP	2	Power failure	Loss of supply	High	Electrician to attend site	Generators to be installed at sites, see actions taken	Emergency Management Plan	Dec-16	Dec 2019 June 2022	Staff time	Operator; Senior staff	Initial-Generators to be installed at Foxdale bores, Coastal WTP, Bowen WTP Generator at Proserpine booster Solar Farm at Bowen WTP to supply plant & grid 2018-Generators installed at Foxdale bores, Dodd St bores, Coastal WTP, Bowen WTP. Solar farm at Bowen WTP operational. Additional generators ordered for Proserpine WTP, Collinsville WTP, Proserpine high lift and a mobile unit. Generators installed at Proserpine WTP, Proserpine High Lift pump and 3 x mobile units. Collinsville unit utilised on other project until Collinsville Solar Project underway See RMP#33 Completed
WTP	3	Instrumentation Failure	Loss of online monitoring	Low		Coastal WTP - Install new analysers at Clear Water Tank	Coastal WTP - upgrade PLC and control telemetry at bores		Short Term July 2018 Long Term July 2019		Treatment Operations Manager	Initial-Analysers received 2018-Completed. Additional work - connecting all bores to SCADA Completed
Reticulation	29	Chlorination failure / Loss of Residual / Chlorinator failure	Public health	High	Isolate Bore 10 from direct connection to potable water network (currently high pressure potable water going to bore)	Initiate Cannonvale Bulk Water Project. Purchase land for Cannon Valley Reservoir. Cannonvale Bulk Water project - Cannonvale network configuration to isolate bulk supply from trunk and reticulation networks, to reduce pressure spikes in network and provide equal water age.	Deliver Cannonvale Bulk Water Project, build Cannon Valley reservoir and renew pipeline from Proserpine.	Short Term 2020-21 Long Term 2021-22			Planning & Assets Engineer - Network Operations Managers COO.	2018-Design complete. Initial project implementation. Bore 10 isolated from network and redirected to Proserpine WTP. Reservoirs x 2 under construction, completion due June 2022 Network reconfiguration after construction completion. June 2022 - Construction complete; Necessary reconfiguration complete. Not on-line as yet. More work required on program and timings for the works required at Coastal WTP. Completed

Reticulation	8	Main bursts / Repairs	Aesthetics / suspended solids / taste & odour	Medium	Monitor flow, reservoir levels, pressure, turbidity. Re-chlorination	Develop a mains burst / repair procedure. Training of operations staff on importance of Hygiene practices (Chlorination of lines following repair, chlorine test on reconnection)	Investigate best-practice chlorination of mains following a repair.	Dec-16	Dec-17	Staff time	Treatment Operations Manager, Network Operations Managers	2018-Completed
Reticulation	12	Cross Contamination (close sewer proximity)	Bacteria, Viral, Protozoa			Develop a mains burst / repair procedure. Training of operations staff on importance of Hygiene practices (Chlorination of lines following repair, chlorine test on reconnection)	Investigate best-practice chlorination of mains following a repair.		Dec-17	Staff time	Treatment Operations Manager, Network Operations Managers	Initial-A chlorination of New mains procedure has been developed. A mains burst / repair procedure will be developed. 2018-Completed. See #8
Reticulation	13	New main connections (contaminating existing system)	Aesthetics / Suspended Solids / Taste, Odour & Colour			Procedure for re-chlorination of new main prior to connection			Complete		Treatment Operations Manager, Network Operations Managers	Initial-A chlorination of New mains procedure has been developed. 2018-Completed. See #8
Recycled Water	14	Cross Connection to recycled water infrastructure	Bacteria, Viral, Protozoa	Low			RPZD's required and to be checked annually	Jun-17	Jun-18	Staff time	Treatment Operations Manager, Network Operations Managers, Team Leaders	Initial-Consolidating this role into a regional one through the trade waste coordinator. 2018-Completed. See #9
Bowen - Proserpine main	15	Main break	Water supply cut off / public health	High	Adhoc repair	Visual check of line and valves.	Full asset check of all line and valves, with asset list and mapping creation. Also preventative maintenance schedule created	June-16	Dec-17	\$40K	Planning & Assets Engineer	Initial-Line has been checked; Check valve being installed south of Whitsunday Shores (2/3 along main) 2018-Completed. Included in maintenance program.
Bowen - Proserpine main	16	Sediment scouring / slime slough	Aesthetics / suspended solids / taste & odour	Medium	Turbidity monitors, lines flushed	Pigging to be undertaken to remove sediment build up	Pigging stations to be constructed		Ongoing	\$8K	Planning & Assets Engineer	Initial-All stations done, worst section of line has been pigged. 2018-Completed. Included in maintenance program.
Storage Reservoirs	19	Pay out of under grade reservoirs.	Public health - Bacteria, Viral and Protozoan contamination	High	At-grade reservoirs have been isolated from system	Assessment of system storage to be completed to determine if at-grade reservoirs need to be on line. Additional sample points to be installed.	If reservoirs are required for satisfactory system operation, reconfiguration of valving to be carried out to ensure water	Dec-15	Jul-18	Staff time	Planning & Assets Engineer - Network Operations Managers COO.	Initial-Assessments complete. Bowen Res - work complete. Hydraulic modelling of Bowen Retic needs recalibration for other reservoirs. Brisk Bay Res - scheduled for 2017-18 2018-Completed. Brisk Bay Res off line until replacement scheduled for 2023-24
Security	23	Terrorism, sabotage	Chemical / Biological	Medium		Review of security at treatment plant sites to ensure access of unauthorised persons is adequately controlled	Preventative maintenance Schedule implemented in councils systems	Dec-15	Dec-17	Staff time	Treatment Operations Manager; Network Operations Managers	Initial-Monthly Reservoir checks have commenced. Action plans will be developed out of these to rectify issues. Emergency Management Plan 2018-Completed
Security	24	Natural Disasters	Cyclone, Earthquake, Flooding etc.	High	Emergency Management Plan	Emergency Management Plan	Emergency Management Plan	Jun-16	Ongoing	Staff time	All Staff	Initial-Emergency Management Plan in effect. Developing a site based cyclone / wet-weather procedure. 2018-Completed