

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
11834	Bowen Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
11834	Bowen Potable Water Scheme	QG1.1	AS2	Length water mains	217.4	km	
11834	Bowen Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	16.5	ML/day	
11834	Bowen Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	17	ML	
							Values inputted into template provided by Qldwater. Template provided follows KPI definitions
11834	Bowen Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	369	ML	
11834	Bowen Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	26.2	per 100 km water main	
11834	Bowen Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	1.2	per 1000 connections	
11834	Bowen Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	4.1	per 1000 connections	
11834	Bowen Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	8.7	per 1000 connections	
11834	Bowen Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	173.7	per 1000 connections	
11834	Bowen Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	4.551	000s	
11834	Bowen Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.596	000s	
11834	Bowen Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
11834	Bowen Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	3.5	per 1000 connections	
11834	Bowen Potable Water Scheme	QG4.1(val PR3		Fixed charge: water value	678	\$/annum	
11834	Bowen Potable Water Scheme	QG4.1(text PR5		Fixed charge: water description		ss charge by prc Text	
11834	Bowen Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	3028	ML	
11834	Bowen Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	0	ML	
11834	Bowen Potable Water Scheme	QG1.5	WA201	Maximum daily demand	10	ML/day	
11834	Bowen Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
11834	Bowen Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
11834	Bowen Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	2742.1	ML	
11834	Bowen Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	1457.4	ML	
11834	Bowen Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	902	ML	
11834	Bowen Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
11834	Bowen Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	3028	ML	
11834	Bowen Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
11834	Bowen Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
11834	Bowen Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
11834	Bowen Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
11834	Bowen Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
11834	Bowen Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
11834	Bowen Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
11834	Bowen Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
11834	Bowen Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
11834	Bowen Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
11834	Bowen Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
11834	Bowen Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
11834	Bowen Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
11834	Bowen Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
11834	Bowen Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Contingency available from Don River bores, chlorinated then direct into reticulations system, can be implemented within 1 day.
1238	Cannonvale Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
1238	Cannonvale Potable Water Scheme	QG1.1	AS2	Length water mains	136.3	km	
1238	Cannonvale Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	11.5	ML/day	
1238	Cannonvale Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	20.34	ML	
							Values inputted into template provided by Qldwater. Template provided follows KPI definitions
1238	Cannonvale Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	533.1	ML	
1238	Cannonvale Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	40.4	per 100 km water main	
1238	Cannonvale Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	1.4	per 1000 connections	
1238	Cannonvale Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	6.4	per 1000 connections	
1238	Cannonvale Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	9.6	per 1000 connections	
1238	Cannonvale Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	80.8	per 1000 connections	
1238	Cannonvale Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	5.841	000s	
1238	Cannonvale Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.706	000s	
1238	Cannonvale Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1238	Cannonvale Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	1.4	per 1000 connections	
1238	Cannonvale Potable Water Scheme	QG4.1(value)	PR3	Fixed charge: water value	678	\$/annum	
1238	Cannonvale Potable Water Scheme	QG4.1(text)	PR5	Fixed charge: water description		ss charge by prc	Text
1238	Cannonvale Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	860.6	ML	
1238	Cannonvale Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	449.1	ML	
1238	Cannonvale Potable Water Scheme	QG1.5	WA201	Maximum daily demand	5	ML/day	
1238	Cannonvale Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	1534.6	ML	
1238	Cannonvale Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
							The difference can be attributed to the different types of meters used at different locations (into and out of Proserpine WTP and what moves to Cannonvale scheme)
1238	Cannonvale Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	1315.7	ML	
1238	Cannonvale Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	1494.1	ML	
1238	Cannonvale Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	808.9	ML	
1238	Cannonvale Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
1238	Cannonvale Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	2844.3	ML	
1238	Cannonvale Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
1238	Cannonvale Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
1238	Cannonvale Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	366	days	
1238	Cannonvale Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
1238	Cannonvale Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
1238	Cannonvale Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
1238	Cannonvale Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
1238	Cannonvale Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
1238	Cannonvale Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
1238	Cannonvale Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
1238	Cannonvale Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
1238	Cannonvale Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
1238	Cannonvale Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
1238	Cannonvale Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1238	Cannonvale Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Contingency available from existing bores, chlorinated then direct into reticulations system, can be implemented within 1 day.
1239	Collinsville Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
1239	Collinsville Potable Water Scheme	QG1.1	AS2	Length water mains	50	km	
1239	Collinsville Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	6.1	ML/day	
1239	Collinsville Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	7.5	ML	
1239	Collinsville Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	159.2	ML	Values inputted into template provided by Qldwater. Template provided follows KPI definitions
1239	Collinsville Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	28	per 100 km water main	
1239	Collinsville Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	3.2	per 1000 connections	
1239	Collinsville Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
1239	Collinsville Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	5.7	per 1000 connections	
1239	Collinsville Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	68.8	per 1000 connections	
1239	Collinsville Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	1.067	000s	
1239	Collinsville Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.169	000s	
1239	Collinsville Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
1239	Collinsville Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0.8	per 1000 connections	
1239	Collinsville Potable Water Scheme	QG4.1(valu	PR3	Fixed charge: water value	678	\$/annum	
1239	Collinsville Potable Water Scheme	QG4.1(text	PR5	Fixed charge: water description	ss charge by prc	Text	
1239	Collinsville Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	1057	ML	
1239	Collinsville Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	0	ML	
1239	Collinsville Potable Water Scheme	QG1.5	WA201	Maximum daily demand	2.7	ML/day	
1239	Collinsville Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
1239	Collinsville Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
1239	Collinsville Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	992.5	ML	
1239	Collinsville Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	295.2	ML	
1239	Collinsville Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	533.1	ML	
1239	Collinsville Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
1239	Collinsville Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	1057	ML	
1239	Collinsville Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1239	Collinsville Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
1239	Collinsville Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
1239	Collinsville Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
1239	Collinsville Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
1239	Collinsville Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
1239	Collinsville Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
1239	Collinsville Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
1239	Collinsville Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
1239	Collinsville Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
1239	Collinsville Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
1239	Collinsville Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
1239	Collinsville Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
1239	Collinsville Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
1239	Collinsville Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Trucking of potable water available from other schemes. Historic bore may be utilised for ong term outages (need 7 days to get online)
11835	Proserpine Potable Water Scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
11835	Proserpine Potable Water Scheme	QG1.1	AS2	Length water mains	69	km	
11835	Proserpine Potable Water Scheme	QG1.4b	AS47	Capacity of water treatment plants	14	ML/day	
11835	Proserpine Potable Water Scheme	QG1.7	AS48	Total potable water storage volume	5.7	ML	
11835	Proserpine Potable Water Scheme	QG1.23	AS56	Volume water lost: potable water	15.6	ML	Values inputted into template provided by Qldwater. Template provided follows KPI definitions
11835	Proserpine Potable Water Scheme	QG4.5	AS8	Water main breaks per 100 km water main	17.4	per 100 km water main	
11835	Proserpine Potable Water Scheme	QG4.12	CS10	Water service complaints per 1000 connections	1	per 1000 connections	
11835	Proserpine Potable Water Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	3.5	per 1000 connections	
11835	Proserpine Potable Water Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	6.5	per 1000 connections	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
11835	Proserpine Potable Water Scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	11	per 1000 connections	
11835	Proserpine Potable Water Scheme	QG1.13	CS2	Connected residential properties: water	1.669	000s	
11835	Proserpine Potable Water Scheme	QG1.14	CS3	Connected non-residential properties: water	0.323	000s	
11835	Proserpine Potable Water Scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
11835	Proserpine Potable Water Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	2	per 1000 connections	
11835	Proserpine Potable Water Scheme	QG4.1(valu	PR3	Fixed charge: water value	678	\$/annum	
11835	Proserpine Potable Water Scheme	QG4.1(text	PR5	Fixed charge: water description	ss charge by prc	Text	
11835	Proserpine Potable Water Scheme	QG1.8	WA1	Volume water sourced: surface water	655.1	ML	
11835	Proserpine Potable Water Scheme	QG1.9a	WA2	Volume water sourced: groundwater	1422.6	ML	
11835	Proserpine Potable Water Scheme	QG1.5	WA201	Maximum daily demand	8	ML/day	
11835	Proserpine Potable Water Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
11835	Proserpine Potable Water Scheme	QG1.22	WA224	Volume all water exported: internal and external	1534.6	ML	
							The difference can be attributed to the different types of meters used at different locations (into and out of Proserpine WTP and what moves to Cannonvale scheme)
11835	Proserpine Potable Water Scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	2101.1	ML	
11835	Proserpine Potable Water Scheme	QG1.17a	WA32	Volume potable water supplied: residential	352	ML	
11835	Proserpine Potable Water Scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	196.1	ML	
11835	Proserpine Potable Water Scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
11835	Proserpine Potable Water Scheme	QG1.12	WA7	Volume water sourced: all	2077.7	ML	
11835	Proserpine Potable Water Scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
11835	Proserpine Potable Water Scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
11835	Proserpine Potable Water Scheme	QG2.10c	WS13	Water restriction duration: Level 2	366	days	
11835	Proserpine Potable Water Scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
11835	Proserpine Potable Water Scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
11835	Proserpine Potable Water Scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
11835	Proserpine Potable Water Scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
11835	Proserpine Potable Water Scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
11835	Proserpine Potable Water Scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
11835	Proserpine Potable Water Scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
11835	Proserpine Potable Water Scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
11835	Proserpine Potable Water Scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	
11835	Proserpine Potable Water Scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
11835	Proserpine Potable Water Scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	Contingency available from existing bores, chlorinated then direct into reticulations system, can be implemented within 1 day.
11835	Proserpine Potable Water Scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	
9711	Bowen Effluent Reuse Scheme	QG1.1	AS2	Length water mains	8.9	km	
9711	Bowen Effluent Reuse Scheme	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
9711	Bowen Effluent Reuse Scheme	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
9711	Bowen Effluent Reuse Scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
9711	Bowen Effluent Reuse Scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
9711	Bowen Effluent Reuse Scheme	QG1.13	CS2	Connected residential properties: water	NR	000s	
9711	Bowen Effluent Reuse Scheme	QG1.14	CS3	Connected non-residential properties: water	0.003	000s	
9711	Bowen Effluent Reuse Scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
9711	Bowen Effluent Reuse Scheme	QG4.1(valu	PR3	Fixed charge: water value	NR	\$/annum	
9711	Bowen Effluent Reuse Scheme	QG4.1(text	PR5	Fixed charge: water description	No Charge	Text	
9711	Bowen Effluent Reuse Scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
9711	Bowen Effluent Reuse Scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
9711	Bowen Effluent Reuse Scheme	QG1.11	WA26	Volume recycled sewage supplied: all	259.4	ML	
9711	Bowen Effluent Reuse Scheme	QG1.12	WA7	Volume water sourced: all	259.4	ML	
9710	Cannonvale Effluent reuse	QG1.1	AS2	Length water mains	0	km	
9710	Cannonvale Effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
9710	Cannonvale Effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
9710	Cannonvale Effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
9710	Cannonvale Effluent reuse	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
9710	Cannonvale Effluent reuse	QG1.13	CS2	Connected residential properties: water	NR	000s	
9710	Cannonvale Effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0	000s	
9710	Cannonvale Effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
9710	Cannonvale Effluent reuse	QG4.1(valu	PR3	Fixed charge: water value	NR	\$/annum	
9710	Cannonvale Effluent reuse	QG4.1(text	PR5	Fixed charge: water description	No Charge	Text	
9710	Cannonvale Effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
9710	Cannonvale Effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
9710	Cannonvale Effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	0	ML	
9710	Cannonvale Effluent reuse	QG1.12	WA7	Volume water sourced: all	0	ML	
11844	Collinsville Effluent reuse	QG1.1	AS2	Length water mains	1.3	km	
11844	Collinsville Effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
11844	Collinsville Effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
11844	Collinsville Effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
11844	Collinsville Effluent reuse	QG4.14	CS12	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
11844	Collinsville Effluent reuse	QG4.11	CS13	connections	0	per 1000 connections	
11844	Collinsville Effluent reuse	QG1.13	CS2	Connected residential properties: water	NR	000s	
11844	Collinsville Effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0.001	000s	
11844	Collinsville Effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
11844	Collinsville Effluent reuse	QG4.1(val	PR3	Fixed charge: water value	NR	\$/annum	
11844	Collinsville Effluent reuse	QG4.1(text	PR5	Fixed charge: water description	No Charge	Text	
11844	Collinsville Effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
11844	Collinsville Effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
11844	Collinsville Effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	106.5	ML	
11844	Collinsville Effluent reuse	QG1.12	WA7	Volume water sourced: all	106.5	ML	
11845	Proserpine Effluent reuse	QG1.1	AS2	Length water mains	1.5	km	
11845	Proserpine Effluent reuse	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
11845	Proserpine Effluent reuse	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
11845	Proserpine Effluent reuse	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
11845	Proserpine Effluent reuse	QG4.14	CS12	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
11845	Proserpine Effluent reuse	QG4.11	CS13	connections	0	per 1000 connections	
11845	Proserpine Effluent reuse	QG1.13	CS2	Connected residential properties: water	NR	000s	
11845	Proserpine Effluent reuse	QG1.14	CS3	Connected non-residential properties: water	0	000s	
11845	Proserpine Effluent reuse	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
11845	Proserpine Effluent reuse	QG4.1(val	PR3	Fixed charge: water value	NR	\$/annum	
11845	Proserpine Effluent reuse	QG4.1(text	PR5	Fixed charge: water description	No Charge	Text	
11845	Proserpine Effluent reuse	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
11845	Proserpine Effluent reuse	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
11845	Proserpine Effluent reuse	QG1.11	WA26	Volume recycled sewage supplied: all	0	ML	
11845	Proserpine Effluent reuse	QG1.12	WA7	Volume water sourced: all	0	ML	
1060	Bowen sewer treatment plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	17.7	per 100 km sewer mains	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1060	Bowen sewer treatment plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
1060	Bowen sewer treatment plant	QG1.2	AS5	Length sewerage mains and channels	135.8	km	
1060	Bowen sewer treatment plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	1.8	per 1000 connections	
1060	Bowen sewer treatment plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
1060	Bowen sewer treatment plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	1.8	per 1000 connections	
1060	Bowen sewer treatment plant	QG1.15	CS6	Connected residential properties: sewerage	3.639	000s	
1060	Bowen sewer treatment plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
1060	Bowen sewer treatment plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.228	000s	
1060	Bowen sewer treatment plant	QG4.2(value PR31		Fixed charge: sewerage value	936	\$/annum	
1060	Bowen sewer treatment plant	QG4.2(text PR40		Fixed charge: sewerage description		is Charge by Pro Text	
11836	Cannonvale Waste Water Treatment Plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	19.3	per 100 km sewer mains	
11836	Cannonvale Waste Water Treatment Plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
11836	Cannonvale Waste Water Treatment Plant	QG1.2	AS5	Length sewerage mains and channels	135	km	
11836	Cannonvale Waste Water Treatment Plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	0.5	per 1000 connections	
11836	Cannonvale Waste Water Treatment Plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
11836	Cannonvale Waste Water Treatment Plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0.8	per 1000 connections	
11836	Cannonvale Waste Water Treatment Plant	QG1.15	CS6	Connected residential properties: sewerage	5.497	000s	
11836	Cannonvale Waste Water Treatment Plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
11836	Cannonvale Waste Water Treatment Plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.482	000s	
11836	Cannonvale Waste Water Treatment Plant	QG4.2(value PR31		Fixed charge: sewerage value	936	\$/annum	
11836	Cannonvale Waste Water Treatment Plant	QG4.2(text PR40		Fixed charge: sewerage description		is Charge by Pro Text	
11837	Collinsville Sewer treatment plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	25.5	per 100 km sewer mains	
11837	Collinsville Sewer treatment plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
11837	Collinsville Sewer treatment plant	QG1.2	AS5	Length sewerage mains and channels	39.1	km	
11837	Collinsville Sewer treatment plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	0.9	per 1000 connections	
11837	Collinsville Sewer treatment plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
11837	Collinsville Sewer treatment plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0.9	per 1000 connections	
11837	Collinsville Sewer treatment plant	QG1.15	CS6	Connected residential properties: sewerage	0.987	000s	
11837	Collinsville Sewer treatment plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
11837	Collinsville Sewer treatment plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.068	000s	
11837	Collinsville Sewer treatment plant	QG4.2(val	PR31	Fixed charge: sewerage value	936	\$/annum	
11837	Collinsville Sewer treatment plant	QG4.2(text	PR40	Fixed charge: sewerage description		is Charge by Pr	Text
1058	Proserpine Sewer Treatment Plant	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	8.2	per 100 km sewer mains	
1058	Proserpine Sewer Treatment Plant	QG1.3	AS4	Number sewage treatment plants	1	Count	
1058	Proserpine Sewer Treatment Plant	QG1.2	AS5	Length sewerage mains and channels	48.7	km	
1058	Proserpine Sewer Treatment Plant	QG4.13	CS11	Sewerage service complaints per 1000 connections	0	per 1000 connections	
1058	Proserpine Sewer Treatment Plant	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
1058	Proserpine Sewer Treatment Plant	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
1058	Proserpine Sewer Treatment Plant	QG1.15	CS6	Connected residential properties: sewerage	1.45	000s	
1058	Proserpine Sewer Treatment Plant	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
1058	Proserpine Sewer Treatment Plant	QG1.16	CS7	Connected non-residential properties: sewerage	0.157	000s	
1058	Proserpine Sewer Treatment Plant	QG4.2(val	PR31	Fixed charge: sewerage value	936	\$/annum	
1058	Proserpine Sewer Treatment Plant	QG4.2(text	PR40	Fixed charge: sewerage description		is Charge by Pr	Text
1375	Whitsunday Regional Council WSP-wide	QG1.4a	AS1	Number water treatment plants: providing full treatment	4	Count	
1375	Whitsunday Regional Council WSP-wide	QG1.1	AS2	Length water mains	484.4	km	
1375	Whitsunday Regional Council WSP-wide	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	17.8	per 100 km sewer mains	
1375	Whitsunday Regional Council WSP-wide	QG1.3	AS4	Number sewage treatment plants	4	Count	
1375	Whitsunday Regional Council WSP-wide	QG1.4b	AS47	Capacity of water treatment plants	48.1	ML/day	
1375	Whitsunday Regional Council WSP-wide	QG1.7	AS48	Total potable water storage volume	50.54	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.2	AS5	Length sewerage mains and channels	358.6	km	
1375	Whitsunday Regional Council WSP-wide	QG1.23	AS56	Volume water lost: potable water	1076.9	ML	
1375	Whitsunday Regional Council WSP-wide	QG4.5	AS8	Water main breaks per 100 km water main	28.5	per 100 km water main	
1375	Whitsunday Regional Council WSP-wide	QG4.12	CS10	Water service complaints per 1000 connections	1.4	per 1000 connections	
1375	Whitsunday Regional Council WSP-wide	QG4.13	CS11	Sewerage service complaints per 1000 connections	0.9	per 1000 connections	
1375	Whitsunday Regional Council WSP-wide	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	4.7	per 1000 connections	
1375	Whitsunday Regional Council WSP-wide	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	9.4	per 1000 connections	
1375	Whitsunday Regional Council WSP-wide	QG4.7	CS17	Average frequency unplanned interruptions: water	102.5	per 1000 connections	
1375	Whitsunday Regional Council WSP-wide	QG1.13	CS2	Connected residential properties: water	13.128	000s	
1375	Whitsunday Regional Council WSP-wide	QG1.14	CS3	Connected non-residential properties: water	1.794	000s	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1375	Whitsunday Regional Council WSP-wide	QG1.15	CS6	Connected residential properties: sewerage	11.573	000s	
1375	Whitsunday Regional Council WSP-wide	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	100	%	
1375	Whitsunday Regional Council WSP-wide	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
1375	Whitsunday Regional Council WSP-wide	QG1.16	CS7	Connected non-residential properties: sewerage	0.935	000s	
1375	Whitsunday Regional Council WSP-wide	QG4.10	CS9	Water quality complaints per 1000 connections	2.1	per 1000 connections	
1375	Whitsunday Regional Council WSP-wide	QG3.9	FN1	Revenue: all (NPR) water	25147.01	\$,000	
				Nominal written down replacement cost: fixed sewerage			
1375	Whitsunday Regional Council WSP-wide	QG3.6	FN10	assets	148273.108	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.11	FN11	Costs: operating water per connection	830.18	\$/connection	
1375	Whitsunday Regional Council WSP-wide	QG3.12	FN12	Costs: operating sewerage per connection	821.03	\$/connection	
1375	Whitsunday Regional Council WSP-wide	QG3.1	FN14	Capital expenditure: water supply	3969.4	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.2	FN15	Capital expenditure: sewerage	2808.137	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.10	FN2	Revenue: all (NPR) sewerage	20352.03	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.3	FN26	Capital works grants: water	749.852	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.4	FN27	Capital works grants: sewerage	0	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.11a	FN32	Costs: operating water (NPR)	12387.968	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.12a	FN33	Costs: operating sewerage	10269.44	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.21	FN49	Costs: any other water	6129.405	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.22	FN50	Costs: any other sewerage	5693.134	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.7	FN74	Current replacement costs: fixed water assets	350954.646	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.8	FN75	Current replacement costs: fixed sewerage assets	240408.962	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.13	FN76	Costs: maintenance water	6331.523	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.14	FN77	Costs: maintenance sewerage	7135.409	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.15	FN78	Current cost depreciation: water	5754.306	\$,000	
1375	Whitsunday Regional Council WSP-wide	QG3.16	FN79	Current cost depreciation: sewerage	4601.439	\$,000	
				Previous 5 year average annual renewals expenditure:			
1375	Whitsunday Regional Council WSP-wide	QG3.17	FN80	water	705	\$,000	
				Previous 5 year average annual renewals expenditure:			
1375	Whitsunday Regional Council WSP-wide	QG3.18	FN81	sewerage	1795	\$,000	
				Forecast 5 year average annual renewals expenditure:			
1375	Whitsunday Regional Council WSP-wide	QG3.19	FN82	water	4582	\$,000	
				Forecast 5 year average annual renewals expenditure:			
1375	Whitsunday Regional Council WSP-wide	QG3.20	FN83	sewerage	3854	\$,000	
				Nominal written down replacement cost: fixed water			
1375	Whitsunday Regional Council WSP-wide	QG3.5	FN9	assets	213607.297	\$,000	Valuation done in 2023-2024
1375	Whitsunday Regional Council WSP-wide	QG4.1(valu	PR3	Fixed charge: water value	678	\$/annum	
1375	Whitsunday Regional Council WSP-wide	QG4.2(valu	PR31	Fixed charge: sewerage value	936	\$/annum	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1375	Whitsunday Regional Council WSP-wide	QG4.2(text	PR40	Fixed charge: sewerage description			
1375	Whitsunday Regional Council WSP-wide	QG4.3	PR47	Annual bill based on 200kL/a: water+sewerage	1856	\$	
1375	Whitsunday Regional Council WSP-wide	QG4.4	PR48	Typical residential bill: water+sewerage	1986	\$	
1375	Whitsunday Regional Council WSP-wide	QG4.1(text	PR5	Fixed charge: water description			
1375	Whitsunday Regional Council WSP-wide	QG1.8	WA1	Volume water sourced: surface water	5600.7	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.9a	WA2	Volume water sourced: groundwater	1871.6	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.5	WA201	Maximum daily demand	25.6	ML/day	
1375	Whitsunday Regional Council WSP-wide	QG1.21	WA223	Volume all water imported: internal and external	1534.6	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.22	WA224	Volume all water exported: internal and external	1534.6	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.6a	WA225	Volume potable water produced at a water treatment plant	7151.5	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.11	WA26	Volume recycled sewage supplied: all	365.9	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.17a	WA32	Volume potable water supplied: residential	3598.7	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.18a	WA34	Volume potable water supplied: non-residential	2440.1	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.10	WA61	Volume water sourced: desalination marine water	0	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.12	WA7	Volume water sourced: all	9372.7	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.17b	WA91	Volume raw-PT water supplied: residential	NR	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	NR	ML	
1375	Whitsunday Regional Council WSP-wide	QG1.20	WF1	Total full-time equivalent water+sewerage employees	69	FTEs	
1375	Whitsunday Regional Council WSP-wide	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
1375	Whitsunday Regional Council WSP-wide	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
1375	Whitsunday Regional Council WSP-wide	QG2.10c	WS13	Water restriction duration: Level 2	366	days	
1375	Whitsunday Regional Council WSP-wide	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
1375	Whitsunday Regional Council WSP-wide	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
1375	Whitsunday Regional Council WSP-wide	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
1375	Whitsunday Regional Council WSP-wide	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
1375	Whitsunday Regional Council WSP-wide	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
1375	Whitsunday Regional Council WSP-wide	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
1375	Whitsunday Regional Council WSP-wide	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	
1375	Whitsunday Regional Council WSP-wide	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
1375	Whitsunday Regional Council WSP-wide	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	5	1,2,3,4,5,6	

2023-2024 DNRME KPI Results - Whitsunday Regional Council

scheme id	scheme name	kpi code	swim code	indicator title	value	units	comments
1375	Whitsunday Regional Council WSP-wide	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
1375	Whitsunday Regional Council WSP-wide	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
1375	Whitsunday Regional Council WSP-wide	QG2.3	WS3	Available contingency supplies	yes	yes/no	