



- NOTES:**
1. Use only with the prior approval of the Service Authority.
 2. MAX sewer size shall be 225 DIA.
 3. Concrete N32 in accordance with AS 1379 and AS 3600.
 4. Covers and frames grey cast iron, grade \geq T-220 to AS 1830
 5. Reinforcing bars Grade 400 to AS/NZS 4671.
 6. Cast iron covers shall be used in roadways and footpaths - Class D to AS 3996.
 7. Concrete filled covers shall be used in private property and Reserves - Class C to AS 3996.
 8. Covers and frames. Bitumen paint to AS/NZS 3750.4.
 9. Alternative C.I. covers are acceptable if manufactured to fit nominated C.I. frames.
 10. Access chambers used as a pressure main discharge chamber or within 100 metres of a pressure main discharge point shall be fully lined with HDPE/PVC material (or equivalent) subject to Council approval.
 11. Roof design to Austroads W7 wheel load, dynamic factor 0.4.
 12. All dimensions in millimetres

| | | |
|-----------|---|----------|
| D | DEVELOPMENT MANUAL UPDATES AND AMENDMENTS 2018 | 26/10/18 |
| C | GENERAL UPDATES AND STANDARD REFERENCING AMENDMENTS | 6/5/16 |
| B | MINOR AMENDMENTS | 10/3/98 |
| A | ORIGINAL ISSUE | 1/3/97 |
| REVISIONS | | DATE |



Email: info@whitsundayrc.qld.gov.au Web: www.whitsundayrc.qld.gov.au

BOWEN
67 Herbert St
Bowen 4805 Q
Ph 07 4761 3600

COLLINSVILLE
Cnr Stanley & Conway Sts
Collinsville 4804 Q
Ph 07 4785 5366

PROSERPINE
83-85 Main St
Proserpine 4800 Q
Ph 07 4945 0200

ACCESS CHAMBERS
RECTANGULAR INCLUDING
C.I. COVERS & FRAMES

SEWERAGE
Standard
Drawing
S-0024

| | | | |
|---|---|---|---|
| A | B | C | D |
|---|---|---|---|